



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Hawthorne Court	Provider Number	001268
Address	524 ELY ,	Approval Status	Approved
City, State, Zip	Kennewick, WA 99336	Facility Type	Residential Care

On 07/24/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 85812

Complaint of smoke detector not working.

On 06/12/2023 at approximately 1000 hours a smoke detector in resident room J7 was discovered without the power light. resident was moved temporarily to another unit until the detector was replaced.

Facility maintenance director consulted with local fire marshal fire alarm company to make corrections. A fire watch on J7 until repaired (06/20/2023 - Fire Protection Specialists).

There was no fire (fire department did not respond). No sprinklers were activated. One resident was relocated (with no injuries).

Next inspection scheduled on or after: *n/a*

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Laurie Hanny
Signature

Laurie Hanny - General Manager
Print Name and Title

Deputy State Fire Marshal Doug DeGraff
143302 E Law Lane
Kennewick WA 98007
(509) 531-3384

[Signature]
Signature