



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Hawthorne Court
Address 524 ELY ,
City, State, Zip Kennewick, WA 99336

Provider Number 001268
Approval Status Approved
Facility Type Residential Care

On 09/16/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 194130

Here's a complaint of Fire alarm

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

On September 17, 2025 an inspection was completed for Hawthorne Court located at 524 N. Ely Street in Kennewick, Washington. The facility had an automatic smoke detector activate on September 8, 2025 in Room J26 at approximately 1300 hours. The fire alarm system activated and the fire department responded to the site and findings were the detection appliance was malfunctioning. The facility contacted the fire alarm servicing company who was able to replace the device at approximately 1400 hours on the same day. No residents or staff were injured and there were no evacuations of the facility. Staff completed a fire watch every 15 minutes to the area affected, and fire watch documentation and supporting fire alarm system reports were provided for review.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Andrea Ely
2715 RUDKIN RD
Union Gap WA
(509) 531-3384

Andrea Ely

Digitally signed by
Andrea Ely
Date: 2025.09.22
17:00:40 -07'00'

Signature