



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Apple Springs Retirement & AL Residence **Provider Number** 001277
Address 1001 SENNA ST. **Approval Status** Approved
City, State, Zip Omak, WA 98841 **Facility Type** Residential Care

On 12/9/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 155882

Here's a complaint of fire system down

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

On December 9, 2024 a site inspection was completed at Apple Springs Retirement located at 1001 Senna Street, in Omak, WA. The site inspection was to complete and investigation into an air compressor that failed on 11/15/2024 at approximately 1815hrs.


The fire department responded and confirmed the equipment failure and discovered water leaking in the sprinkler riser room. The system was temporarily deactivated as water was removed, and the facility was placed into an immediate fire watch by the fire department. The facility contacted their fire sprinkler contractor, who arrived on 11/15 at 1000hrs to repair the system. Contractors installed a replacement air compressor and the fire alarm and suppression system were back in service on 11/16 at 1115hrs.

Fire watch documentation (11/15-1815hrs to 11/16-1415hrs) was provided by the facility for review on site. No evacuation was conducted, and no staff or residents were harmed or affected by the system outage.

Next inspection scheduled on or after:


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Devan Cooper - ED
Print Name and Title

Deputy State Fire Marshal Andrea Ely
2715 RUDKIN RD
Union Gap WA
(509) 531-3384


Signature

Initials of Authorized Facility Representative: _____