



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Apple Springs Retirement & AL Residence	Provider Number	001277
Address	1001 SENNA ST ,	Approval Status	Approved
City, State, Zip	Omak, WA 98841	Facility Type	Residential Care

On 11/12/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 197904 Here's a complaint of Fire watch Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? No fire occurred. 2. If the sprinklers were activated? No 3. If there was an evacuation / how many were evacuated? 0 4. If there were injuries / how many? 0 5. Did the fire department respond? Yes	On November 12, 2025 an inspection was completed at Apple Springs Retirement located at 1001 Senna Street in Omak, Washington for a complaint #197904 of a fire alarm system out of service. The Administrative Director and Maintenance Manager were interviewed regarding a system failure that occurred on October 6, 2025 at approximately 1130 hours. The fire alarm system activated and the fire department responded and it was determined that the accelerator was not connected, which caused a loss of pressure to the sprinkler system. The facility immediately went into fire watch and contacted their alarm service company for service repairs at approximately 1230 hours. There was no fire within the facility, no evacuations, no injuries to residents or staff, but the fire department did respond. The fire alarm system was out of service for two days until the fire alarm technician completed the repairs and restoration to the system. Fire watch documentation was observed on site which was completed from October 6, 2025 from 1130 hours to October 9, 2025 to 1230 hours. Reports on site indicated repairs and the system was placed back into service observed on site.
--	---

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Apple Springs Retirement & AL Residence	Provider Number	001277
Address	1001 SENNA ST ,	Approval Status	Approved
City, State, Zip	Omak, WA 98841	Facility Type	Residential Care


On 11/12/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Dean Cooper Executive Director
Print Name and Title

Deputy State Fire Marshal Andrea Ely
2715 RUDKIN RD
Union Gap WA
(509) 531-3384

Andrea Ely

Digitally signed by
Andrea Ely
Date: 2025.11.17
13:03:08 -08'00'

Signature

This document was prepared by Residential Care Services for the Locator website.