



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Cheney Assisted Living
Address 2229 N 6TH ST ,
City, State, Zip Cheney, WA

Provider Number 001326
Approval Status Approved
Facility Type Residential Care

On 04/28/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin - (ITM) Inspection, Testing, & Maintenance

Any citation that requires inspection, testing, or maintenance (ITM) is required to have the testing completed, paper results delivered, and any deficiencies found during the ITM corrected before the citation is cleared."

For your information.

2 Cleaning

Hoods, grease-removal devices, fans, ducts and other appurtenances shall be cleaned at intervals as required by Sections 606.3.3.1 through 606.3.3.3.
(IFC 606.3.3 2021)

The following violation was observed:

The kitchen suppression system hood grates are dirty.

Cleaned at inspection.

3 Penetrations - Maintaining Protection

Materials and firestop systems used to protect membrane and through penetrations in fire-resistance-rated construction and construction installed to resist the passage of smoke shall be maintained. The materials and firestop systems shall be securely attached to or bonded to the construction being penetrated with no openings visible through or into the cavity of the construction. Where the system design number is known, the system shall be inspected to the listing criteria and manufacturer's installation instructions.
(IFC 703.1 2021)

The following violation was observed:

The ceiling grate was missing in the kitchen mop closet.

Corrected at inspection.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cheney Assisted Living	Provider Number	001326
Address	2229 N 6TH ST ,	Approval Status	Approved
City, State, Zip	Cheney, WA	Facility Type	Residential Care

On 04/28/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

before the active lead

9. Latching hardware operates and secures the door when it is in the closed position

10. Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame

11. No field modification to the door assembly have been performed that void the label.

12. Meeting edge protection, gasketing and edge seals where required, are inspected to verify their presence and integrity

13. Signage affixed to a door meets the requirements listed in 4.1.4


4.1.4 Signage. Informational signs shall be permitted to be installed on the surfaces of fire doors in accordance with 4.1.4.1 through 4.1.4.4 or in accordance with the manufacturer's published listing.

4.1.4.1 The total area of all attached signs shall not exceed 5 percent of the area of the face of the fire door to which they are attached.

Next inspection scheduled on or after: 05/31/2027

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Zach Thieffault Main: Mgr
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 964-2746

Barbara R.
McMullen
Digitally signed by
Barbara R. McMullen
Date: 2026.04.29
09:55:13 -07'00'

Signature