



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Orchard Park Assisted Living	Provider Number	001350
Address	844 ORCHARD ,	Approval Status	Approved
City, State, Zip	Bellingham, WA 98225	Facility Type	Residential Care

On 04/07/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Signature

Ruth Collier Admin.
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Orchard Park Assisted Living	Provider Number	001350
Address	844 ORCHARD	Approval Status	Disapproved
City, State, Zip	Bellingham, WA 98225	Facility Type	Residential Care

On 02/20/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Corrected

2 Inspection and Maintenance

Fire department connections shall be periodically inspected, tested and maintained in accordance with NFPA 25. Records of inspection, testing and maintenance shall be maintained.

(IFC 912.7 2021)


Facility was unable to provide documentation that the Fire Department Connection has been hydrostatically tested in accordance with NFPA 25.

Update: The hydrostatic test has failed. Facility has been working with a vendor and the city of Bellingham to have a lining installed to fire department connection piping.

Next inspection scheduled on or after: 03/22/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Ruth Gollen Admin
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037


Signature



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Orchard Park Assisted Living
Address 844 ORCHARD ,
City, State, Zip Bellingham, WA 98225

Provider Number 001350
Approval Status Disapproved
Facility Type Residential Care

On 12/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Open electrical terminations

Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes. (IFC 603.2.2, 2021)	Corrected	
---	-----------	--

2 Application and Use

603.5.2 Application and use. Relocatable power taps and current taps shall be directly connected to a permanently installed receptacle. Exceptions: 1. Where approved for use in a Group A occupancy or in a meeting room in a Group B occupancy, not more than five relocatable power taps shall be permitted to be connected together or connected to an extension cord for temporary use to supply power to electronic equipment. 2. Current taps and relocatable power taps shall not be required to connect directly to a permanently installed receptacle outlet where used for 90 days or less for the purpose of testing the performance of such devices. (IFC 603.5.2, 2021)	Corrected	
---	-----------	--

3 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.. (IFC 603.6 2021)	Corrected	
---	-----------	--

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Orchard Park Assisted Living
Address 844 ORCHARD ,
City, State, Zip Bellingham, WA 98225

Provider Number 001350
Approval Status Disapproved
Facility Type Residential Care

On 12/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
4 Door Operation	
Swinging fire doors shall close from the full-open position and latch automatically. (IFC 705.2.4 2021)	Corrected
5 Testing and Maintenance	
Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	1. Facility is unable to provide documentation for the 3 year dry system full flow trip test. 2. Facility is unable to provide documentation for the annual forward flow test in accordance with NFPA 25.
6 Inspection, Testing and Maintenance	
The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	Corrected
7 Inspection and Maintenance	
Fire department connections shall be periodically inspected, tested and maintained in accordance with NFPA 25. Records of inspection, testing and maintenance shall be maintained. (IFC 912.7 2021)	Facility was unable to provide documentation that the Fire Department Connection has been hydrostatically tested in accordance with NFPA 25.
8 Maintenance	
Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	Corrected

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Orchard Park Assisted Living
Address 844 ORCHARD ,
City, State, Zip Bellingham, WA 98225

Provider Number 001350
Approval Status Disapproved
Facility Type Residential Care

On 12/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

9 Securing Compressed Gas Containers, Cylinders and Tanks

Compressed gas containers, cylinders and tanks shall be secured to prevent falling caused by contact, vibration or seismic activity. Securing of compressed gas containers, cylinders and tanks shall be by one of the following methods:

1. Securing containers, cylinders and tanks to a fixed object with one or more restraints.
2. Securing containers, cylinders and tanks on a cart or other mobile device designed for the movement of compressed gas containers, cylinders or tanks.
3. Nesting of compressed gas containers, cylinders and tanks at container filling or servicing facilities or in sellers' warehouses not open to the public. Nesting shall be allowed provided that the nested containers, cylinders or tanks, if dislodged, do not obstruct the required means of egress.
4. Securing of compressed gas containers, cylinders and tanks to or within a rack, framework, cabinet or similar assembly designed for such use.

Exception: Compressed gas containers, cylinders and tanks in the process of examination, filling, transport or servicing.

(IFC 5303.5.3 2021)

Corrected



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Orchard Park Assisted Living
Address 844 ORCHARD ,
City, State, Zip Bellingham, WA 98225

Provider Number 001350
Approval Status Disapproved
Facility Type Residential Care

On 12/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.


Code Requirement

Statement of Violation

Next inspection scheduled on or after: 01/23/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Kyle Meade Maintenance Manager
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037


Signature

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Orchard Park Assisted Living
Address 844 ORCHARD ,
City, State, Zip Bellingham, WA 98225

Provider Number 001350
Approval Status Disapproved
Facility Type Residential Care

On 09/17/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Open electrical terminations

Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.

(IFC 603.2.2, 2021)

There was on open junction box in the maintenance office.

2 Application and Use

603.5.2 Application and use. Relocatable power taps and current taps shall be directly connected to a permanently installed receptacle.

Exceptions:

1. Where approved for use in a Group A occupancy or in a meeting room in a Group B occupancy, not more than five relocatable power taps shall be permitted to be connected together or connected to an extension cord for temporary use to supply power to electronic equipment.

2. Current taps and relocatable power taps shall not be required to connect directly to a permanently installed receptacle outlet where used for 90 days or less for the purpose of testing the performance of such devices.

(IFC 603.5.2, 2021)

There is a power strip plugged into another power strip in the nurses station in the nurses office.

3 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors..

(IFC 603.6 2021)

There was an extension cord utilized as permanent wiring in the following locations:

1. Room 315
2. Hallway near 317
3. 2nd floor activities room x2
4. Maintenance office
5. 1st floor nurses station



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Orchard Park Assisted Living
Address 844 ORCHARD ,
City, State, Zip Bellingham, WA 98225

Provider Number 001350
Approval Status Disapproved
Facility Type Residential Care

On 09/17/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

4 Door Operation

Swinging fire doors shall close from the full-open position and latch automatically.

(IFC 705.2.4 2021)

1. The fire rated cross corridor door near room 313 would not close and latch from the fully open position.

2. The fire rated cross corridor door to the dining room would not close and latch from the fully open position.

5 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

1. Facility is unable to provide documentation for the 3 year dry system full flow trip test.

2. Facility is unable to provide documentation for the annual forward flow test in accordance with NFPA 25.

3. Facility is unable to provide documentation for the quarterly sprinkler system inspections.

4. There is storage blocking the sprinkler head in the storage room near 207.

5. The hydraulic calculation plate for wet system 1 and 2 is missing.

6 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

1. The smoke detector head located near 316 has been installed within 36 inches of an air supply diffuser or return air opening. This is preventing proper operation of the smoke detector.

2. The smoke detector head located near 333 has been installed within 36 inches of an air supply diffuser or return air opening. This is preventing proper operation of the smoke detector.

3. There are several standalone smoke alarms with in the resident rooms that are great than 10 year old.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Orchard Park Assisted Living
Address 844 ORCHARD ,
City, State, Zip Bellingham, WA 98225

Provider Number 001350
Approval Status Disapproved
Facility Type Residential Care

On 09/17/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

7 Inspection and Maintenance

Fire department connections shall be periodically inspected, tested and maintained in accordance with NFPA 25. Records of inspection, testing and maintenance shall be maintained.

(IFC 912.7 2021)

Facility was unable to provide documentation that the Fire Department Connection has been hydrostatically tested in accordance with NFPA 25.

8 Maintenance

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required.

(IFC 1203.4 2021)

Facility is unable to provide documentation for the annual servicing of the emergency generator.

9 Securing Compressed Gas Containers, Cylinders and Tanks

Compressed gas containers, cylinders and tanks shall be secured to prevent falling caused by contact, vibration or seismic activity. Securing of compressed gas containers, cylinders and tanks shall be by one of the following methods:

1. Securing containers, cylinders and tanks to a fixed object with one or more restraints.
2. Securing containers, cylinders and tanks on a cart or other mobile device designed for the movement of compressed gas containers, cylinders or tanks.
3. Nesting of compressed gas containers, cylinders and tanks at container filling or servicing facilities or in sellers' warehouses not open to the public. Nesting shall be allowed provided that the nested containers, cylinders or tanks, if dislodged, do not obstruct the required means of egress.
4. Securing of compressed gas containers, cylinders and tanks to or within a rack, framework, cabinet or similar assembly designed for such use.

Exception: Compressed gas containers, cylinders and tanks in the process of examination, filling, transport or servicing.

(IFC 5303.5.3 2021)

Oxygen cylinders in the 3rd floor storage room #5 are not secured to prevent the cylinders from falling.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Orchard Park Assisted Living	Provider Number	001350
Address	844 ORCHARD ,	Approval Status	Disapproved
City, State, Zip	Bellingham, WA 98225	Facility Type	Residential Care

On 09/17/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 10/17/2024

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Ruth Goller
Signature

Ruth Goller Admin
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

[Signature]
Signature