



Washington State Patrol
Fire Protection Bureau

Phone: (360) 596-3900

Business Name Bethany Place Inc
Address 9111 N UPRIVER DR ,
City, State, Zip Spokane, WA 99206

Provider Number 001552
Approval Status Approved
Facility Type Residential Care

On 05/01/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Maintenance Required

Whenever required for compliance with the provisions of this code, devices, equipment, systems, conditions, arrangements, levels of protection or other features shall thereafter be continuously maintained in accordance with applicable NFPA requirements or as directed by the fire code official.

(IFC 907.8.1 2021)

Items listed have been corrected/resolved. Precision Electric report received.

Next inspection scheduled on or after: 05/31/2026


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Daniel Davis
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746


Signature



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Bethany Place Inc	Provider Number	001552
Address	9111 N UPRIVER DR ,	Approval Status	Disapproved
City, State, Zip	Spokane, WA 99206	Facility Type	Residential Care

On 03/25/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin - (ITM) Inspection, Testing, & Maintenance

Any citation that requires inspection, testing, or maintenance (ITM) is required to have the testing completed, paper results delivered, and any deficiencies found during the ITM corrected before the citation is cleared."

For you information on all fire and life safety systems.

2 Relocatable power taps and current taps

Relocatable power taps and current taps. The construction and use of current taps and relocatable power taps shall be in accordance with NFPA 70 and this code.

(IFC 603.5, 2021)

1. In the administrators office there is a heater plugged into a powerstrip.
REMOVED AT INSPECTION.

2. In the 1st floor staff room there is a refrigerator plugged into a powerstrip.
REMOVED AT INSPECTION.

3 Maintenance Required

Whenever required for compliance with the provisions of this code, devices, equipment, systems, conditions, arrangements, levels of protection or other features shall thereafter be continuously maintained in accordance with applicable NFPA requirements or as directed by the fire code official.

(IFC 907.8.1 2021)

On the 3/6/25 fire alarm annual report from Precision Electrical Systems, there are items listed of repairs/unsatisfactory results that require attention.

"Both NAC panels batteries failed load tests. Both NE 1st and 2nd floor notification devices activate briefly, then quit working. Room 46 detector #41 is a heat detector instead of a smoke detector. Horn/Strobes on the 2nd floor connector hallway and in the basement are not working. Basement (west) dry system; the tamper switches, the missing a low air switch and the pressure switch are not connected to the fire alarm system."

DLB



Washington State Patrol
Fire Protection Bureau

Phone: (360) 596-3900

Business Name	Bethany Place Inc	Provider Number	001552
Address	9111 N UPRIVER DR ,	Approval Status	Disapproved
City, State, Zip	Spokane, WA 99206	Facility Type	Residential Care

On 03/25/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 04/24/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Daniel Davis 3-25-25

Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Signature

This document was prepared by Residential Care Services for the Locator website.