



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Canterbury Gardens
Address 1457 3RD AVE ,
City, State, Zip Longview, WA

Provider Number 001580
Approval Status Approved
Facility Type Residential Care

On 04/08/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature


Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 852-0966


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Canterbury Gardens
Address 1457 3RD AVE ,
City, State, Zip Longview, WA

Provider Number 001580
Approval Status Disapproved
Facility Type Residential Care

On 02/27/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Owner's Responsibility

The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space.

(IFC 701.6 2021)

Hole in fire rated construction rose storage room

Repaired 3/6/26
along with mag Storage Rm

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Facility failed to provide forward flow test on sprinkler system

3/10/26 8:00 Am

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Canterbury Gardens	Provider Number	001580
Address	1457 3RD AVE ,	Approval Status	Disapproved
City, State, Zip	Longview, WA	Facility Type	Residential Care

On 02/27/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 03/29/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Julie Medack
Signature

Julie Medack, Executive Director
Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 852-0966

Nicholas D. Wolden
Signature

This document was prepared by Residential Care Services for the Locator website.