



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Garden Terrace Healthcare Ctr of Federal Way	Provider Number	001631
Address	491 S 338TH ST ,	Approval Status	Approved
City, State, Zip	Federal Way, WA 98003	Facility Type	Residential Care

On 05/07/2024 the Office of the State Fire Marshal conducted an inspection at your facility.


All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

Gary Harwood (Dir. Maint.)
Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796


Signature

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Garden Terrace Healthcare Ctr of Federal Way	Provider Number	001631
Address	491 S 338TH ST ,	Approval Status	Disapproved
City, State, Zip	Federal Way, WA 98003	Facility Type	Residential Care

On 03/21/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Administration

	On 03/21/2024 an unannounced Fire and Life Safety Code inspection was conducted at Garden Terrace Healthcare Center of Federal Way by a representative of the Washington State Patrol, State Fire Marshal's Office to determine compliance with all applicable codes. The following deficiencies were cited as a result of this inspection:
--	---

2 Inspection, Testing and Maintenance

Fire protection and life safety systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection and life safety systems and equipment shall be inspected, tested and maintained or removed in accordance with Section 901.8. (IFC 901.6 2021)	The following violation was observed at the time of inspection: The following locations have loaded sprinkler heads: 1. Kitchen 2. Laundry room
--	---

3 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion. (IFC 904.13.5.2 2021)	The following violation was observed at the time of inspection: The facilities hood suppression report shows it is yellowed tagged.
--	---

4 Hangers and Brackets

Hand-held portable fire extinguishers, not housed in cabinets, shall be installed on the hangers or brackets supplied. Hangers or brackets shall be securely anchored to the mounting surface in accordance with the manufacturer's installation instructions. (IFC 906.7 2021)	The following violation was observed at the time of inspection: The fire extinguisher in the Riser room is not properly mounted.
---	--



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Garden Terrace Healthcare Ctr of Federal Way	Provider Number	001631
Address	491 S 338TH ST ,	Approval Status	Disapproved
City, State, Zip	Federal Way, WA 98003	Facility Type	Residential Care

On 03/21/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 04/20/2024

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Gary Harwood
Signature

Gary Harwood 4-7-24
Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796

Cozetta
Signature

This document was prepared by Residential Care Services for the Locator website.