



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Brookdale Nine Mile	Provider Number 001698
Address 5329 W RIFLE CLUB ,	Approval Status Approved
City, State, Zip Spokane, WA	Facility Type Residential Care

On 01/08/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

IEFP report dated 12/15/25 received.

(IFC 903.5 2021)

Next inspection scheduled on or after: 12/31/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

CAMMIE WESTON, MAINTENANCE
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219

Barbara R.

McMullen

Signature

Digitally signed by Barbara R.
McMullen
Date: 2026.01.09 05:36:35 -08'00'



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Nine Mile	Provider Number	001698
Address	5329 W RIFLE CLUB ,	Approval Status	Disapproved
City, State, Zip	Spokane, WA	Facility Type	Residential Care

On 12/11/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin - (ITM) Inspection, Testing, & Maintenance

Any citation that requires inspection, testing, or maintenance (ITM) is required to have the testing completed, paper results delivered, and any deficiencies found during the ITM corrected before the citation is cleared."

For your information.

2 Relocatable power taps and current taps

Relocatable power taps and current taps. The construction and use of current taps and relocatable power taps shall be in accordance with NFPA 70 and this code.

(IFC 603.5, 2021)

The following violations were observed:

Sales/Marketing office had two refrigerators plugged into a powerstrip.

Removed at inspection.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Nine Mile	Provider Number	001698
Address	5329 W RIFLE CLUB ,	Approval Status	Disapproved
City, State, Zip	Spokane, WA	Facility Type	Residential Care

On 12/11/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

3 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

The following violations were observed:

Forward flow testing of the backflow preventers shall be required.

NFPA 25 13.7.2. Testing.

13.7.2.1* All backflow preventers installed in fire protection system piping shall be exercised annually by conducting a forward flow test at a minimum flow rate of the system demand.

13.7.2.1.1 Where water rationing is enforced during shortages lasting more than 1 year, an internal inspection of the backflow preventer to ensure the check valves will fully open shall be permitted in lieu of conducting the annual forward flow test.

13.7.2.1.2 The forward flow test shall not be required where annual fire pump testing causes the system flow rate to flow through the backflow preventer device.

13.7.2.2 Where hydrants or inside hose stations are located downstream of the backflow preventer, the forward flow test shall include hose stream demand.

13.7.2.3 Where connections do not permit verification of the forward flow test at the minimum flow rate of system demand, test shall be conducted at maximum flow rate possible.

The full flow test of the backflow prevention valve can be performed with a test header or other connections downstream of the valve. A bypass around the check valve in the fire department connection line with a control valve in the normally closed position can be an acceptable arrangement. When flow to a visible drain cannot be accomplished, closed loop flow can be acceptable if a flowmeter or sight glass is incorporated into the system to ensure flow.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Nine Mile	Provider Number	001698
Address	5329 W RIFLE CLUB ,	Approval Status	Disapproved
City, State, Zip	Spokane, WA	Facility Type	Residential Care

On 12/11/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 01/10/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

CAMMIE WESTON, MAINTENANCE
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746


Signature

This document was prepared by Residential Care Services for the Locator website.