



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Puyallup South	Provider Number	001702
Address	8811 176TH ST E,	Approval Status	Disapproved
City, State, Zip	Puyallup, WA	Facility Type	Residential Care

On 08/25/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 189695

Here's a complaint of Fire Alarm

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

COMPLAINT # 189695

On August 25, 2025 a complaint investigation was conducted at Brookdale Puyallup South located at 8811 176th Street East, Puyallup, WA 98375.

An interview was conducted with facility staff. Fire alarm was in trouble due to a memory care resident destroying a pull station. Fire alarm is operational and monitoring company is getting a signal but pull station still needs to be fixed. After further inspection it appears that fire alarm panel display at entry way is not currently working.

There was no fire, the sprinkler system did not activate, there were no injuries and the fire department did respond.

The following violations shall be corrected.

2 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

Findings during inspection were:

Fire alarm pull station shall be fixed.

Fire alarm display panel in front entry way is not working and shall be fixed.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Brookdale Puyallup South
Address 8811 176TH ST E,
City, State, Zip Puyallup, WA

Provider Number 001702
Approval Status Disapproved
Facility Type Residential Care

On 08/25/2025 the Office of the State Fire Marshal conducted an inspection at your facility.


Code Requirement

Statement of Violation

Next inspection scheduled on or after: 09/25/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Daina Jones Maintenance
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067


Signature

This document was prepared by Residential Care Services for the Locator website.