




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Regency on Whidbey	Provider Number	1739
Address	1040 SW KIMBALL DR ,	Approval Status	Approved
City, State, Zip	Oak Harbor, WA	Facility Type	Residential Care

On 03/10/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

JEFF LUAN MAINT. DIRECTOR
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Regency on Whidbey	Provider Number	1739
Address	1040 SW KIMBALL DR ,	Approval Status	Disapproved
City, State, Zip	Oak Harbor, WA	Facility Type	Residential Care

On 01/05/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Testing

Horizontal and vertical sliding and rolling fire doors shall be inspected and tested annually to confirm proper operation and full closure. Records of inspections and testing shall be maintained. (IFC 705.2.6 2018)	Facility was unable to provide documentation for the annual testing the rolling fire doors located in the reception area.
---	---

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	As per provide documentation, the latest annual sprinkler system inspection conducted on 10/7/2025 had multiple deficiency that has not been corrected. a. 20 year quick response sprinkler head testing is due. b. 2 recalled sprinkler heads in both 2nd floor laundry rooms. c. 4 painted sprinkler heads
--	---

3 Maintenance

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	Facility is unable to provide documentation for the annual servicing of the emergency generator.
--	--

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Regency on Whidbey	Provider Number	1739
Address	1040 SW KIMBALL DR ,	Approval Status	Disapproved
City, State, Zip	Oak Harbor, WA	Facility Type	Residential Care

On 01/05/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 02/04/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Wilma Jo Flaherty
Signature

Wilma Jo Flaherty Exec. Dir
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037

[Signature]
Signature

This document was prepared by Residential Care Services for the Locator website.