



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Park Vista Retirement & Assisted Living Community	Provider Number	1810
Address	2944 Lund AVE ,	Approval Status	Approved
City, State, Zip	Port Orchard, WA	Facility Type	Residential Care

On 11/06/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 198004 Here's a complaint of Smoking Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	COMPLAINT # 198004 On 11/6/2025 a complaint investigation was conducted at Park Vista Retirement & Assisted Living Community located at 2944 SE Lund Avenue, Port Orchard, WA 98366. An interview was conducted with facility staff. A resident started a fire in the smoking area. Facility has changed all chair to plastic chairs instead of cushion chairs as well as added a fire extinguisher to the smoking area. Facility has also created a smoking schedule for resident in question. There was a fire outside due to a burning chain in the smoking area, the fire sprinkler system did not activate, the fire alarm did not activate, there were no injuries, and the fire department did not respond.
---	--

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Priscilla Adhison
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Signature