



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                                                   |                        |                  |
|-------------------------|---------------------------------------------------|------------------------|------------------|
| <b>Business Name</b>    | Park Vista Retirement & Assisted Living Community | <b>Provider Number</b> | 1810             |
| <b>Address</b>          | 2944 Lund AVE ,                                   | <b>Approval Status</b> | Approved         |
| <b>City, State, Zip</b> | Port Orchard, WA                                  | <b>Facility Type</b>   | Residential Care |

On 12/17/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 202529

Here's a complaint of Fire Alarm

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

COMPLAINT # 202529

On 12/17/2025 a complaint investigation was conducted at Park Vista Retirement and Assisted Living Community located at 2944 SE Lund Avenue, Port Orchard, WA 98366.

An interview was conducted with facility staff. Complaint was in regard to a resident on the 3rd floor not hearing the fire alarm but seeing fire trucks respond to the building. The initial alarm was for burn beans in one of the independent living units. A discussion was had with staff not to silence the alarm as that is the duty of the local fire department upon their arrival. I had the facility activate the fire alarm system and verified that horns and strobes were working on the 3rd, 2nd and 1st floor.

There was no fire, the sprinkler system did not activate, there were no evacuations, there were no injuries, the fire alarm did activate and the fire department responded.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

NOT AVAILABLE  
Signature

\_\_\_\_\_  
Print Name and Title

Deputy State Fire Marshal Raul Murcia  
PO BOX 42642  
Olympia WA 98504  
(360) 819-0067

[Signature]  
Signature