



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fairwinds Redmond	Provider Number	1814
Address	9988 AVONDALE RD NE,	Approval Status	Approved
City, State, Zip	Redmond, WA 98052	Facility Type	Residential Care

On 05/16/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 130854

Here's a complaint of broken sprinkler head

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

ON 5/16/2024, DSFM entered Fairwinds Redmond located at 9988 Avondale Rd NE, Redmond Wa 98052 investigate complaint ref # 130854.

What happened: On the 11th of May 2024 at approximately 9:30 AM

Reporter stated:

"Maintenance worker was painting [painting] the ceiling of empty apartment #350 when he accidentally hit the sprinkler head causing it to go off along with the fire alarm. Water damage done to apartment # below. Notified family and we moved her immediately to apartment # two doors down that was vacant. No interruptions of AL services.

No injuries were reports.

Staff stated the following:

Local fire department responded approximately 9:45am. Fire department checked the affected floors and secured the sprinkler system. No smoke or fire damage occurred. Sprinkler system ran for about 30 minutes. Local fire department activated fire watch for the facility starting at 12:00pm 6:00pm on 5/11/2024. Per Cintas report they arrived at 2:00 pm and had the system resolved and reported normal at 4:30 pm on 5/11/2024. A recovery company is working to resolve the water damaged.

No IFC violations observed from inspection performed on 5/16/2024

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Fairwinds Redmond	Provider Number	1814
Address	9988 AVONDALE RD NE,	Approval Status	Approved
City, State, Zip	Redmond, WA 98052	Facility Type	Residential Care

On 05/16/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2803 156 AVE SE
Bellevue WA 98007
(509) 406-7209

Jason E Van Gorkum
Signature

This document was prepared by Residential Care Services for the Locator website.