



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Bridge Assisted Living at Mount Vernon, The	Provider Number	1826
Address	301 S LAVENTURE RD ,	Approval Status	Approved
City, State, Zip	Mount Vernon, WA 98273	Facility Type	Residential Care

On 09/28/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Signature

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

Signature

Print Name and Title

Anthony DeVries
Maintenance
Director

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Bridge Assisted Living at Mount Vernon, The	Provider Number	1826
Address	301 S LAVENTURE RD ,	Approval Status	Disapproved
City, State, Zip	Mount Vernon, WA 98273	Facility Type	Residential Care

On 08/28/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
1 Extension Cords Extension cords and flexible cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors. (IFC 604.5 2018)	The following violations were observed: 1. There was an extension cord utilized as permanent wiring in the kitchen powering a plate warmer. 2. There was an extension cord utilized as permanent wiring in the Resident Care Director office.
2 Testing and Maintenance Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2009, 2012, 2015, 2018)	The following violations were observed: 1. As per documents provided the full trip test conducted on 9/14/22 did not trip within 60 seconds. 2. There was 2 sprinkler heads in the kitchen that is loaded with combustible materials (lint). 3. There was a dry sprinkler heads, dated from 1997, that was found inside the walk-in refrigerator and freezer.
3 Extinguishing System Service Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion. (IFC 904.12.5.2 2018)	The following violations were observed: Facility is unable to provide documentation for the semi-annual kitchen suppression system servicing.
4 Inspection, Testing and Maintenance The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2018)	The following violations were observed: The fire alarm system has an active supervisory alarm for the backflow tamper switch.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Bridge Assisted Living at Mount Vernon, The	Provider Number	1826
Address	301 S LAVENTURE RD ,	Approval Status	Disapproved
City, State, Zip	Mount Vernon, WA 98273	Facility Type	Residential Care

On 08/28/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 09/27/2023

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner/Authorized Representative

Signature

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

Signature

Print Name and Title

Michael DeMiles
Maintenance Director

This document was prepared by Residential Care Services for the Locator website.