



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900


Business Name	Bridge Assisted Living at Mount Vernon, The	Provider Number	1826
Address	301 S LAVENTURE RD ,	Approval Status	Approved
City, State, Zip	Mount Vernon, WA	Facility Type	Residential Care

On 10/08/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature


Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Bridge Assisted Living at Mount Vernon, The	Provider Number	1826
Address	301 S LAVENTURE RD ,	Approval Status	Disapproved
City, State, Zip	Mount Vernon, WA	Facility Type	Residential Care

On 08/28/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	1. Facility is unable to provide documentation for the annual forward flow test in accordance with NFPA 25. 2. Facility is unable to provide documentation for the quarterly sprinkler system inspections. Missing quarters 2 and 4.
--	---

2 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion. (IFC 904.13.5.2 2021)	As per documents provided the semi-annual kitchen suppression system servicing conducted on 8/18/2025 had deficiencies noted that have not been corrected.
---	--

3 Emergency Power for Illumination - General

In the event of power supply failure in rooms and spaces that require two or more exits or access to exits, an emergency electrical system shall automatically illuminate all of the following areas: 1. Aisles 2. Corridors 3. Exit access stairways and ramps (IFC 1008.3.1 2021)	The emergency egress light/exit sign combo in the activity room would not illuminate when the test button was pressed.
---	--

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900


Business Name	Bridge Assisted Living at Mount Vernon, The	Provider Number	1826
Address	301 S LAVENTURE RD ,	Approval Status	Disapproved
City, State, Zip	Mount Vernon, WA	Facility Type	Residential Care


On 08/28/2025 the Office of the State Fire Marshal conducted an inspection at your facility.


Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 09/27/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature


Print Name and Title
Anthony DeVries
Main Director

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

Signature

This document was prepared by Residential Care Services for the Locator website.