



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Liberty Shores Assisted Living Ret Community	Provider Number	1834
Address	19360 Viking AVE NE,	Approval Status	Approved
City, State, Zip	Poulsbo, WA	Facility Type	Residential Care

On 01/05/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Aaron Melius
Signature

AARON MELIUS DIRECTOR OF MAINTENANCE
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

R. Murcia
Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Liberty Shores Assisted Living Ret Community	Provider Number	1834
Address	19360 Viking AVE NE,	Approval Status	Disapproved
City, State, Zip	Poulsbo, WA	Facility Type	Residential Care

On 09/30/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Abatement of Electrical Hazards

Abatement of unsafe conditions and electrical hazards. Conditions that constitute an electrical shock or fire hazard shall be abated..

(IFC 603.2 2021)

Findings during inspection were:

1st floor staff lunge has an electrical outlet by coffee machine that is not connected to the wall stud.

1st floor laundry room has old lights on ceiling with exposed wires.

Conditions that constitute an electrical shock or fire hazard shall be abated.

2 Appliance Connection to Building Piping

Gas-fired commercial cooking appliances installed on casters and appliances that are moved for cleaning and sanitation purposes shall be connected to the piping system with an appliance connector listed as complying with ANSI Z21.69/CSA 6.16. The commercial cooking appliance connector installation shall be configured in accordance with the manufacturer's installation instructions. Movement of appliances with casters shall be limited by a restraining device installed in accordance with the connector and appliance manufacturer's instructions.

(IFC 606.4 2021)

Findings during inspection were:

Facility failed to maintain kitchen cooking appliances. All gas appliances shall be tethered to the wall.

3 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Findings during inspection were:

Facility failed to maintain sprinkler heads in the following locations;

-2nd floor of Harbor House in day room, sprinkler head loaded with debris.

-Kitchen cooler, sprinkler head loaded with debris.

-1st floor laundry, sprinkler head loaded with debris.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Liberty Shores Assisted Living Ret Community	Provider Number	1834
Address	19360 Viking AVE NE,	Approval Status	Disapproved
City, State, Zip	Poulsbo, WA	Facility Type	Residential Care

On 09/30/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

4 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

Findings during inspection were:

Fire alarm report from 6-12-25 states strobe inoperable in 2nd floor Harbor House dining area.

Next inspection scheduled on or after: 11/01/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Aaron Melius
Signature

AARON MELIUS DIRECTOR OF MAINT.
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

[Signature]
Signature

This document was prepared by Residential Care Services for the Locator website.