



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Gleed Orchard Manor	Provider Number	001916
Address	30 Link RD ,	Approval Status	Approved
City, State, Zip	Naches, WA 98937	Facility Type	Residential Care

On 03/13/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Smoking General

The smoking or carrying of a lighted pipe, cigar, cigarette or any other type of smoking paraphernalia or material is prohibited in the areas indicated in Sections 310.2 through 310.8.

(IFC 310.1 2015, 2018)

The following violation was observed:

Smoking materials were found outside of the ashtrays in the patio area outside. (corrected)

2 Abatement of Electrical Hazards

Abatement of unsafe conditions and electrical hazards. Conditions that constitute an electrical shock or fire hazard shall be abated..

(IFC 603.2 2021)

The following violation was observed:

There was a portable heater outside in the smoking area (for animal use) that was plugged in but not operational. (corrected)

Next inspection scheduled on or after: 03/31/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Linda Wyatt
Signature

Linda Wyatt Environmental Coordinator
Print Name and Title

Deputy State Fire Marshal Andrea Ely
2715 RUDKIN RD
Union Gap WA
(509) 531-3384

Andrea Ely
Signature