



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Ashley Gardens at Mount Vernon

Provider Number 1948

Address 3807 E College WAY ,

Approval Status Approved


City, State, Zip Mount Vernon, WA 98273


Facility Type Residential Care

On 02/26/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature


Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Ashley Gardens at Mount Vernon
Address 3807 E College WAY ,
City, State, Zip Mount Vernon, WA 98273

Provider Number 1948
Approval Status Disapproved
Facility Type Residential Care

On 01/14/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Emergency Power for Illumination - General

In the event of power supply failure in rooms and spaces that require two or more exits or access to exits, an emergency electrical system shall automatically illuminate all of the following areas:

1. Aisles
2. Corridors
3. Exit access stairways and ramps

(IFC 1008.3.1 2021)

The emergency egress light in "C" community above rear exit would not illuminate when the test button was pressed.

2 Internally Illuminated Exit Signs

Electrically powered, self-luminous and photoluminescent exit signs shall be listed and labeled in accordance with UL 924 and shall be installed in accordance with the manufacturer's instructions and Section 1203. Exit signs shall be illuminated at all times.

(IFC 1013.5 2021)

The internally illuminated exit signs in "B" community above front exit would not illuminate when the activation test button was pushed.

Next inspection scheduled on or after: 02/13/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

Signature

Initials of Authorized Facility Representative: _____