



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                             |                        |                  |
|-------------------------|-----------------------------|------------------------|------------------|
| <b>Business Name</b>    | Providence Mount St Vincent | <b>Provider Number</b> | 198              |
| <b>Address</b>          | 4831 35TH AVE SW,           | <b>Approval Status</b> | Approved         |
| <b>City, State, Zip</b> | Seattle, WA                 | <b>Facility Type</b>   | Residential Care |

On 11/18/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 200803

Here's a complaint of Fire Alarm

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

Next inspection scheduled on or after:

On 11/18/2025 an unannounced complaint inspection was conducted at Providence Mount St Vincent. The fire alarm panel CPU was determined to be faulty. The facility performed fire watch and contacted the appropriate people. The fire alarm was repaired and the facility stopped their fire watch.

The facility is in compliance at this time

**Right of appeal.** Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Alberto N. Angilio, Dir of Opr

Print Name and Title

Deputy State Fire Marshal Kimberly Bloor  
PO Box 42600  
Olympia WA 985042600  
(360) 596-3922

Kimberly Bloor

Digitally signed by Kimberly Bloor  
Date: 2025.11.24 14:02:46 -08'00'

Signature