



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Sessions Residential Care Inc	Provider Number	1999
Address	22 N ADAMS RD ,	Approval Status	Approved
City, State, Zip	Spokane Valley, WA 99216	Facility Type	Residential Care

On 06/06/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 181710

Here's a complaint of a fire in mop closet.

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? Electrical Fire in Fan Box in mop closet.
2. If the sprinklers were activated? No
3. If there was an evacuation / how many were evacuated? Yes, 24
4. If there were injuries / how many? None
5. Did the fire department respond? Yes

On June 6, 2025, a representative from the State Fire Marshals Office entered Sessions Residential Care facility in regard to a complaint about fire in the Mop Closet.

Residents observed smoke coming out of a vent in the wall outside and notified staff. Staff evacuated building and contacted the fire department. Fire department came out and assessed the situation, determined cause of the fire from a fan box that reached a temperature of over 185 degrees, the plastic water pipe burst putting out the fire. The building was cleared by the fire department within an hour.

Maintenance has contacted electrician, fire sprinkler contractor, DOH/CRS, local jurisdiction. All maintenance items have been resolved.

Staff followed procedures.

There are no code violations cited.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Sessions Residential Care Inc	Provider Number	1999
Address	22 N ADAMS RD ,	Approval Status	Approved
City, State, Zip	Spokane Valley, WA 99216	Facility Type	Residential Care

On 06/06/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Crystal Hopkins
Signature

Crystal Hopkins House
Print Name and Title
manager

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746

Barbara
Signature

This document was prepared by Residential Care Services for the Locator website.