



Washington State Patrol
Fire Protection Bureau

Phone: (360) 596-3900

Business Name	Sessions Residential Care Inc	Provider Number	1999
Address	22 N ADAMS RD ,	Approval Status	Approved
City, State, Zip	Spokane Valley, WA	Facility Type	Residential Care

On 02/19/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin - (ITM) Inspection, Testing, & Maintenance

Any citation that requires inspection, testing, or maintenance (ITM) is required to have the testing completed, paper results delivered, and any deficiencies found during the ITM corrected before the citation is cleared."

For your information.

2 Relocatable power taps and current taps

Relocatable power taps and current taps. The construction and use of current taps and relocatable power taps shall be in accordance with NFPA 70 and this code.

(IFC 603.5, 2021)

The following violations were observed:

In room 14 there was a powerstrip daisy chained into another powerstrip.

REMOVED AT INSPECTION.

3 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors..

(IFC 603.6 2021)

The following violations were observed:

In room 14 there was an unapproved extension cord in use.

REMOVED AT INSPECTION.

This document was prepared by Residential Care Services for the Locator website



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Sessions Residential Care Inc	Provider Number	1999
Address	22 N ADAMS RD ,	Approval Status	Approved
City, State, Zip	Spokane Valley, WA	Facility Type	Residential Care

On 02/19/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 03/31/2027

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Crystal Hopkins House Manager
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99218
(509) 954-2746


Signature

This document was prepared by Residential Care Services for the Locator website.