



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Florence of Seattle LLC	Provider Number	2011
Address	8424 16TH AVE SW,	Approval Status	Approved
City, State, Zip	Seattle, WA 98106	Facility Type	Residential Care

On 06/04/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

[Signature]
Signature

Laurie Yamashita Administrator
Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2803 156 AVE SE
Bellevue WA 98007
(509) 406-7209

Jason Van Gorkum
Date: 2025.06.16
12:55:46 -07'00'

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Florence of Seattle LLC
Address 8424 16TH AVE SW,
City, State, Zip Seattle, WA 98106

Provider Number 2011
Approval Status Disapproved
Facility Type Residential Care

On 01/09/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Administration

Facility will need documentation showing the upgrade of the commercial stove. This will be done through Construction Review Search, WSDH.

2 Cleaning

Hoods, grease-removal devices, fans, ducts and other appurtenances shall be cleaned at intervals as required by Sections 606.3.3.1 through 606.3.3.3.

(IFC 606.3.3 2021)

At time of inspection the following was observed:

1. Facility will need to have exhaust fans tested.

3 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

The following deficiencies were cited as a result of this inspection:

At the time of inspection, the following paperwork was not provided:

1. Annual forward flow test (NFPA 25 13.7.2)
2. Quarterly inspections

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Florence of Seattle LLC	Provider Number	2011
Address	8424 16TH AVE SW,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98106	Facility Type	Residential Care

On 01/09/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

4 Circuit identification and Accessibility

10.6.5.2 Circuit Identification and Accessibility.
10.6.5.2.1 The location of the branch circuit disconnecting means shall be permanently identified at the control unit.
10.6.5.2.2 System circuit disconnecting means shall be permanently identified as to its purpose in accordance with the following:
(1) "FIRE ALARM" for fire alarm systems
(2) "EMERGENCY COMMUNICATIONS" for emergency communications systems
(3) "FIRE ALARM/ECS" for combination fire alarm and emergency communications systems
10.6.5.2.3 For fire alarm and/or signaling systems, the circuit disconnecting means shall have a red marking.
10.6.5.2.4 The red marking shall not damage the overcurrent protective devices or obscure the manufacturer's markings.
10.6.5.2.5 The circuit disconnecting means shall be accessible only to authorized personnel.
10.6.5.3 Mechanical Protection. The branch circuit(s) and connections shall be protected against physical damage.
10.6.5.4 Circuit Breaker Lock. Where a circuit breaker is the disconnecting means, a listed breaker locking device shall be installed.
10.6.5.5 Overcurrent Protection. An overcurrent protective device of suitable current-carrying capacity that is capable of interrupting the maximum short-circuit current to which it can be subject shall be provided in each ungrounded conductor.
(NFPA 72 10.6.5.2)

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Florence of Seattle LLC	Provider Number	2011
Address	8424 16TH AVE SW,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98106	Facility Type	Residential Care

On 01/09/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------


Next inspection scheduled on or after: 02/20/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative




Signature



Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2803 156 AVE SE
Bellevue WA 98007
(509) 406-7209



Signature

This document was prepared by Residential Care Services for the Locator website.