



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Bonaventure of the Tri-Cities
Address 1800 BELLERIVE ,
City, State, Zip Richland, WA 99352

Provider Number 2015
Approval Status Approved
Facility Type Residential Care

On 01/18/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 114495

1. The cause of the fire? N/A
2. If the sprinklers were activated? Frozen fire sprinkler pipes.
3. If there was an evacuation / how many were evacuated? No.
4. If there were injuries / how many? None.
5. Did the fire department respond? Yes.

This report is the result of off-site fire and life safety complaint investigation at Bonaventure of Tri Cities in Richland, Washington on January 18, 2024 and February 8, 2024. The survey was conducted by staff from the Washington State Patrol, Fire Protection Bureau. Complaint Case #114495.

Internal sprinkler system repairs have been completed. One head on exterior of building in independent resident area has been ordered. Facility shall provide final fire watch documentation and contractor's report.

There were no citations were issued.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

INSPECTION VIA EMAIL & TELEPHONE
Signature

Print Name and Title

Deputy State Fire Marshal Barbara Maier
PO BOX 42642
Olympia WA 98504
(360) 596-3925

Signature