



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Bonaventure of East Wenatchee	Provider Number	2026
Address	50 29th ST NW,	Approval Status	Approved
City, State, Zip	East Wenatchee, WA 98802	Facility Type	Residential Care

On 04/09/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 218350

Here's a complaint of Kitchen towels caught fire

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

On April 9, 2026 a site inspection was completed at Bonaventure of East Wenatchee located at 50 29th Street NW, in East Wenatchee, Washington for complaint #218350 of a fire that started in the 1st floor Laundry Room on March 28, 2026.

At approximately 1200 hours, a Housekeeping staff member noticed a light smell of smoke within the first floor and notified Facilities Staff to assist in investigating the cause of the smell. Staff members found a small crate of mop heads and towels smoldering in the Laundry Room on the shelf across from the industrial washer and dryer. The combustibles had not produced any ignition sources at that time, but were causing a significant amount of light gray smoke within the room.

Staff immediately closed the Laundry Room door and contacted emergency dispatch services. Both staff members had experienced smoke inhalation while investigating, and the smoke detector within the room activated the fire alarm. Staff began closing doors on the first floor and assisted all residents located in the first floor in evacuations.

No fire suppression systems were activated and there were no injuries to residents. Both staff members were assessed by first responders and taken to the local hospital for observation, and were released. During the evacuation, Dietary Staff brought out refreshments and water for residents who were outside for approximately one hour, while the Fire Department responded and reset the fire alarm system.

The facility followed their Fire Response Policy during the emergency and are holding an After Action Report meeting at the all staff meeting on April 9, 2026. Residents were given a copy of the policy as a reminder of what to do in an emergency. No violations were noted.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Bonaventure of East Wenatchee	Provider Number	2026
Address	50 29th ST NW,	Approval Status	Approved
City, State, Zip	East Wenatchee, WA 98802	Facility Type	Residential Care

On 04/09/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Andrea Ely
2715 RUDKIN RD
Union Gap WA
(509) 531-3384

Andrea Ely

Digitally signed by
Andrea Ely
Date: 2026.04.09
11:35:39 -07'00'

Signature

This document was prepared by Residential Care Services for the Locator website.