



Washington State Patrol

Fire Protection Bureau

Phone: (360) 596-3900

Business Name Horizon House
Address 900 UNIVERSITY ST ,
City, State, Zip Seattle, WA 98101

Provider Number 000212
Approval Status Approved
Facility Type Residential Care

On 8/3/2023 the Office of the State Fire Marshal conducted an inspection at your facility.


All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

Sean McMahon Chief Engineer
Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2803 156 AVE SE
Bellevue WA 98007
(509) 406-7209


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 6/28/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Multiplug Adapters

Multiplug adapters, such as cube adapters, unfused plug strips or any other device not complying with NFPA 70 shall be prohibited.

(IFC 604.4 2018)

At time of inspection the following was observed:

1. power extension cord in EVS room, 2nd floor east tower

2 Owner's Responsibility

The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space.

(IFC 701.6 2018 WAC 51-54A)

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Facility will need to identify and establish a schedule for inspection of Fire-Rated construction by 30 days of this inspection.
2. Annual inspection of fire-resistance-rated construction will need to be performed and completed by end of 2023.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

3 Penetrations - Maintaining Protection

Materials and firestop systems used to protect membrane and through penetrations in fire-resistance-rated construction and construction installed to resist the passage of smoke shall be maintained. The materials and firestop systems shall be securely attached to or bonded to the construction being penetrated with no openings visible through or into the cavity of the construction. Where the system design number is known, the system shall be inspected to the listing criteria and manufacturer's installation instructions.

(IFC 703.1 2018)

At time of inspection the following was observed:

1. 3rd floor electrical room, north tower
2. 3rd floor electrical south side, north tower
3. 3rd floor trash room/soiled utility, center tower
4. 2nd floor electrical room by room 243, East tower
5. 2nd floor electrical room by 226, north tower

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Horizon House	Provider Number 000212
Address 900 UNIVERSITY ST,	Approval Status Disapproved
City, State, Zip Seattle, WA 98101	Facility Type Residential Care

On 6/28/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

4 Door Operation

Swinging fire doors shall close from the full-open position and latch automatically. (IFC 705.2.4 2018)	At time of inspection the following was observed: 1. 3rd floor double doors by room 301, center tower 2. 2nd floor double doors by room 228, north tower 3. 2nd floor double doors by room 217, north tower
--	--

5 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2009, 2012, 2015, 2018)	At time of inspection the following was observed: 1. bent or dirty head under hood in kitchen
--	--

6 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion. (IFC 904.12.5.2 2018)	The following deficiencies were cited as a result of this inspection: At the time of inspection the following paperwork was not provided: 1. First semi-annual servicing 2. Second semi-annual service 3. Annual replacement of fusible links/auto sprinkler heads (IFC 904.12.5.3) All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.
---	---

7 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2018)	At time of inspection the following was observed: 1. broken detector next to elevator in kitchen
--	---

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 6/28/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

8 Exit Signs

Exit signs shall be installed and maintained in accordance with the building code that was in effect at the time of construction and the applicable provisions in Section 1104. Decorations, furnishings, equipment or adjacent signage that impairs the visibility of exit signs, creates confusion or prevents identification of the exit shall not be allowed.

(IFC 1031.4 2018)

At time of inspection the following was observed:

1. broken exit sign next to "exit stairway" in kitchen

9 NFPA 80 Fire /Smoke Dampers Inspection and Testing

19.4 Periodic Inspection and Testing.
19.4.1 Each damper shall be tested and inspected 1 year after installation.
19.4.1.1 The test and inspection frequency shall then be every 4 years, except in hospitals, where the frequency shall be every 6 years.

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Document showing that all deficiencies have been corrected.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol

Fire Protection Bureau

Phone: (360) 596-3900

Business Name Horizon House
Address 900 UNIVERSITY ST ,
City, State, Zip Seattle, WA 98101

Provider Number 000212
Approval Status Disapproved
Facility Type Residential Care

On 6/28/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

10 NFPA 80 Fire Door Inspection and Testing

5.2.1 Inspection and Testing. Upon completion of the installation, door, shutters, and window assemblies shall be inspected and tested in accordance with 5.2.4.

5.2.4 Periodic Inspection and Testing.

5.2.4.1 Periodic inspections and testing shall be performed not less than annually.

5.2.2.4 A record of all inspections and testing shall be provided that includes, but is not limited to, the following information:

1. Date of inspection
2. Name of facility
3. Address of facility
4. Name of person(s) performing inspections and testing
5. Company name and address of inspecting company
6. Signature of inspector of record
7. Individual record of each inspected and tested fire door assembly
8. Opening identifier and location of each inspected and tested fire door assembly
9. Type and description of each inspected and tested fire door assembly
10. Verification of visual inspection and functional operation
11. Listing of deficiencies in accordance with 5.2.3, Section 5.3, and Section 5.4

And the following shall be checked:

1. Labels are clearly visible and legible
2. No open holes or breaks exist in surfaces of wither the door or frame
3. Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.
4. The door, frame, hinges, hardware, and non combustible threshold are secured, aligned and in working order with no visible, signs of damage
5. No parts are missing or broken
6. Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7
7. The self-closing device is operational,; that is, the active door completely closes when operated from the full open position
8. If a coordinator is installed, the inactive lead close before the active lead

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Facility will need to identify and establish a schedule for inspection of Fire Doors by 30 days of this inspection.
2. Annual inspection of fire doors will need to be performed and completed by end of 2023.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol

Fire Protection Bureau

Phone: (360) 596-3900

Business Name Horizon House
Address 900 UNIVERSITY ST.,
City, State, Zip Seattle, WA 98101

Provider Number 000212
Approval Status Disapproved
Facility Type Residential Care

On 6/28/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
9. Latching hardware operates and secures the door when it is in the closed position 10. Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame 11. No field modification to the door assembly have been preformed that void the label. 12. Meeting edge protection, gasketing and edge seals where required, are inspected to verify their presence and intertie 13. Signage affixed to a door meets the requirements listed in 4.1.4	

Next inspection scheduled on or after: 7/31/2023


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Sean McMahan Chief Engineer
Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2803 156 AVE SE
Bellevue WA 98007
(360) 481-3933


Signature