




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Approved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 05/20/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

Sean McMahan Chief Engineer
Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2803 156 AVE SE
Bellevue WA 98007
(509) 406-7209

Jason Van Gorkum
Date: 2025.05.20
Signature
13:56:27 -07'00'

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 02/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Time

Drills shall be held at unexpected times and under varying conditions to simulate the unusual conditions that occur in case of fire.

Exceptions:

1. In severe climates, the fire code official shall have the authority to modify the emergency evacuation drill termination points and frequency.
2. In Groups I-1, I-2, I-3 and R-4, where staff-only emergency evacuation drills are conducted after visiting hours or where care recipients are expected to be asleep, a coded announcement shall be an acceptable alternative to audible alarms.

(IFC 405.2 2021)

Records shall be maintained of required emergency evacuation drills and include the following information:

1. Identity of the person conducting the drill.
2. Date and time of the drill.
3. Notification method used.
4. Employees on duty and participating.
5. Number of occupants evacuated.
6. Special conditions simulated.
7. Problems encountered.
8. Weather conditions when occupants were evacuated.
9. Time required to accomplish complete evacuation.

(IFC 0405.6 2021)

Corrected

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 02/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

2 Application and Use

603.5.2 Application and use. Relocatable power taps and current taps shall be directly connected to a permanently installed receptacle.

Exceptions:

1. Where approved for use in a Group A occupancy or in a meeting room in a Group B occupancy, not more than five relocatable power taps shall be permitted to be connected together or connected to an extension cord for temporary use to supply power to electronic equipment.
2. Current taps and relocatable power taps shall not be required to connect directly to a permanently installed receptacle outlet where used for 90 days or less for the purpose of testing the performance of such devices.

(IFC 603.5.2, 2021)

Corrected

3 Cleaning

Hoods, grease-removal devices, fans, ducts and other appurtenances shall be cleaned at intervals as required by Sections 606.3.3.1 through 606.3.3.3.

(IFC 606.3.3 2021)

Corrected

4 Owner's Responsibility

The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space.

(IFC 701.6 2021)

Corrected

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 02/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

5 Door Operation

Swinging fire doors shall close from the full-open position and latch automatically.

(IFC 705.2.4 2021)

Corrected

6 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Corrected

7 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.

(IFC 904.13.5.2 2021)

At time of Re-inspection the following was observed:

1. Deficiencies found on report. Facility is upgrading wet system to UL300.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Horizon House
Address 900 UNIVERSITY ST ,
City, State, Zip Seattle, WA 98101

Provider Number 000212
Approval Status Disapproved
Facility Type Residential Care

On 02/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

8 Portable Fire Extinguishers - General Requirements

Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Exceptions:

1. The distance of travel to reach an extinguisher shall not apply. The travel distance to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies.

2. Thirty-day inspections shall not be required and maintenance shall be allowed to be once every three years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met:

2.1. Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed.

2.2. Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal.

2.3. The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment.

2.4. Electronic monitoring devices and supervisory circuits shall be tested every 3 years when extinguisher maintenance is performed.

2.5. A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10.

3. In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations.

(IFC 906.2 2021)

Corrected

9 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

Corrected

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Horizon House
Address 900 UNIVERSITY ST ,
City, State, Zip Seattle, WA 98101

Provider Number 000212
Approval Status Disapproved
Facility Type Residential Care

On 02/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

10 Carbon Monoxide Detection - General

Carbon monoxide detection shall be installed in new buildings in accordance with Sections 915.1.1 through 915.6. Carbon monoxide detection shall be installed in existing buildings in accordance with Chapter 11 of the International Fire Code.

(IFC 0915.1 2021 WAC 51-54A)

Corrected

11 Emergency Lighting Equipment Inspection and Testing

Emergency lighting shall be maintained in accordance with Section 1008 and shall be inspected and tested in accordance with Sections 1031.10.1 and 1031.10.2.

(IFC 1032.10 2021)

Corrected

12 Activation Test

Emergency lighting equipment shall be tested monthly for a duration of not less than 30 seconds. The test shall be performed manually or by an automated self-testing and self-diagnostic routine. Where testing is performed by self-testing and self-diagnostics, a visual inspection of the emergency lighting equipment shall be conducted monthly to identify any equipment displaying a trouble indicator or that has become damaged or otherwise impaired.

(IFC 1032.10.1 2021)

Corrected

13 Power Test

Battery-powered emergency lighting equipment shall be tested annually by operating the equipment on battery power for not less than 90 minutes.

(IFC 1031.10.2 2021)

Corrected

14 Maintenance

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required.

(IFC 1203.4 2021)

Corrected

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 02/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

15 NFPA 80 Fire /Smoke Dampers Inspection and Testing

19.4 Periodic Inspection and Testing.
19.4.1 Each damper shall be tested and inspected 1 year after installation.
19.4.1.1 The test and inspection frequency shall then be every 4 years, except in hospitals, where the frequency shall be every 6 years.

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Fire/smoke damper inspection will need to be performed and documented

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Horizon House
Address 900 UNIVERSITY ST ,
City, State, Zip Seattle, WA 98101

Provider Number 000212
Approval Status Disapproved
Facility Type Residential Care

On 02/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

16 NFPA 80 Fire Door Inspection and Testing

5.2.1 Inspection and Testing. Upon completion of the installation, door, shutters, and window assemblies shall be inspected and tested in accordance with 5.2.4.

5.2.4 Periodic Inspection and Testing.

5.2.4.1 Periodic inspections and testing shall be performed not less than annually.

5.2.2.4 A record of all inspections and testing shall be provided that includes, but is not limited to, the following information:

1. Date of inspection
2. Name of facility
3. Address of facility
4. Name of person(s) performing inspections and testing
5. Company name and address of inspecting company
6. Signature of inspector of record
7. Individual record of each inspected and tested fire door assembly
8. Opening identifier and location of each inspected and tested fire door assembly
9. Type and description of each inspected and tested fire door assembly
10. Verification of visual inspection and functional operation
11. Listing of deficiencies in accordance with 5.2.3, Section 5.3, and Section 5.4

And the following shall be checked:

1. Labels are clearly visible and legible
2. No open holes or breaks exist in surfaces of wither the door or frame
3. Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.
4. The door, frame, hinges, hardware, and non combustible threshold are secured, aligned and in working order with no visible, signs of damage
5. No parts are missing or broken
6. Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7
7. The self-closing device is operational,; that is, the active door completely closes when operated from the full open position
8. If a coordinator is installed, the inactive lead close before the active lead

Corrected

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 02/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
9. Latching hardware operates and secures the door when it is in the closed position 10. Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame 11. No field modification to the door assembly have been performed that void the label. 12. Meeting edge protection, gasketing and edge seals where required, are inspected to verify their presence and integrity 13. Signage affixed to a door meets the requirements listed in 4.1.4	

Next inspection scheduled on or after: 03/05/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature


Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2803 156 AVE SE
Bellevue WA 98007
(509) 406-7209


Signature

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Time

Drills shall be held at unexpected times and under varying conditions to simulate the unusual conditions that occur in case of fire. Exceptions: 1. In severe climates, the fire code official shall have the authority to modify the emergency evacuation drill termination points and frequency. 2. In Groups I-1, I-2, I-3 and R-4, where staff-only emergency evacuation drills are conducted after visiting hours or where care recipients are expected to be asleep, a coded announcement shall be an acceptable alternative to audible alarms. (IFC 405.2 2021) Records shall be maintained of required emergency evacuation drills and include the following information: 1. Identity of the person conducting the drill. 2. Date and time of the drill. 3. Notification method used. 4. Employees on duty and participating. 5. Number of occupants evacuated. 6. Special conditions simulated. 7. Problems encountered. 8. Weather conditions when occupants were evacuated. 9. Time required to accomplish complete evacuation. (IFC 0405.6 2021)	Corrected
---	-----------

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
2 Application and Use	
603.5.2 Application and use. Relocatable power taps and current taps shall be directly connected to a permanently installed receptacle. Exceptions: 1. Where approved for use in a Group A occupancy or in a meeting room in a Group B occupancy, not more than five relocatable power taps shall be permitted to be connected together or connected to an extension cord for temporary use to supply power to electronic equipment. 2. Current taps and relocatable power taps shall not be required to connect directly to a permanently installed receptacle outlet where used for 90 days or less for the purpose of testing the performance of such devices. (IFC 603.5.2, 2021)	At time of inspection the following was observed: 1. There was a power strip plugged into another power strip in memory care closets dining room. 2. multi extension cord found in use in hallway outside of office AL3
3 Cleaning	
Hoods, grease-removal devices, fans, ducts and other appurtenances shall be cleaned at intervals as required by Sections 606.3.3.1 through 606.3.3.3. (IFC 606.3.3 2021)	Corrected
4 Owner's Responsibility	
The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space. (IFC 701.6 2021)	At the time of inspection the following paperwork was not provided: 1. Facility will need to identify and establish a schedule for inspection of Fire-Rated construction. Annual inspection of fire-resistance-rated construction will need to be performed and completed. All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
5 Door Operation	
Swinging fire doors shall close from the full-open position and latch automatically. (IFC 705.2.4 2021)	At time of inspection the following was observed: 1. Double doors by room 317 will not latch
6 Testing and Maintenance	
Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Corrected 1. Facility is working to resolve communication between fire pump and generator.
7 Extinguishing System Service	
Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion. (IFC 904.13.5.2 2021)	At time of Re-inspection the following was observed: 1. Deficiencies found on report. Facility is upgrading wet system to UL300.

Need to go thru Council

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

8 Portable Fire Extinguishers - General Requirements

Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Exceptions:

1. The distance of travel to reach an extinguisher shall not apply. The travel distance to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies.
2. Thirty-day inspections shall not be required and maintenance shall be allowed to be once every three years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met:
 - 2.1. Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed.
 - 2.2. Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal.
 - 2.3. The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment.
 - 2.4. Electronic monitoring devices and supervisory circuits shall be tested every 3 years when extinguisher maintenance is performed.
 - 2.5. A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10.
3. In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations.

(IFC 906.2 2021)

At time of inspection the following was observed:

1. Facility will need to perform an audit of fire extinguishers through building. A good number of fire extinguishers show that they have not been inspected since 2022.

This document was prepared by Residential Care Services for the locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Horizon House
Address 900 UNIVERSITY ST ,
City, State, Zip Seattle, WA 98101
Provider Number 000212
Approval Status Disapproved
Facility Type Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

9 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Annual report
2. Sensitivity Testing (IFC 907.8.3)
3. Monthly single and multiple station alarms test (IFC 907.8)

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

At time of inspection the following was observed:

1. Communication part of the fire alarm system was in trouble

10 Carbon Monoxide Detection - General

Carbon monoxide detection shall be installed in new buildings in accordance with Sections 915.1.1 through 915.6. Carbon monoxide detection shall be installed in existing buildings in accordance with Chapter 11 of the International Fire Code.

(IFC 0915.1 2021 WAC 51-54A)

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Carbon Monoxide Alarms and Detectors will need to be tested, maintained and documented on a monthly schedule.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

11 Emergency Lighting Equipment Inspection and Testing

Emergency lighting shall be maintained in accordance with Section 1008 and shall be inspected and tested in accordance with Sections 1031.10.1 and 1031.10.2.

(IFC 1032.10 2021)

At time of inspection the following was observed:

1. Exit sign not working located out reverse door AL2



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
12 Activation Test	
Emergency lighting equipment shall be tested monthly for a duration of not less than 30 seconds. The test shall be performed manually or by an automated self-testing and self-diagnostic routine. Where testing is performed by self-testing and self-diagnostics, a visual inspection of the emergency lighting equipment shall be conducted monthly to identify any equipment displaying a trouble indicator or that has become damaged or otherwise impaired. (IFC 1032.10.1 2021)	Corrected ✓
13 Power Test	
Battery-powered emergency lighting equipment shall be tested annually by operating the equipment on battery power for not less than 90 minutes. (IFC 1031.10.2 2021)	Corrected ✓
14 Maintenance	
Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	The following deficiencies were cited as a result of this inspection: At the time of inspection the following paperwork was not provided: 1. Annual service report 2. Log of weekly inspections 3. Monthly 30-minute full load test ✓ All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
15 NFPA 80 Fire /Smoke Dampers Inspection and Testing	
19.4 Periodic Inspection and Testing. 19.4.1 Each damper shall be tested and inspected 1 year after installation. 19.4.1.1 The test and inspection frequency shall then be every 4 years, except in hospitals, where the frequency shall be every 6 years.	The following deficiencies were cited as a result of this inspection: At the time of inspection the following paperwork was not provided: 1. Fire/smoke damper inspection will need to be performed and documented All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

16 NFPA 80 Fire Door Inspection and Testing

5.2.1 Inspection and Testing. Upon completion of the installation, door, shutters, and window assemblies shall be inspected and tested in accordance with 5.2.4.

5.2.4 Periodic Inspection and Testing.

5.2.4.1 Periodic inspections and testing shall be performed not less than annually.

5.2.2.4 A record of all inspections and testing shall be provided that includes, but is not limited to, the following information:

1. Date of inspection
2. Name of facility
3. Address of facility
4. Name of person(s) performing inspections and testing
5. Company name and address of inspecting company
6. Signature of inspector of record
7. Individual record of each inspected and tested fire door assembly
8. Opening identifier and location of each inspected and tested fire door assembly
9. Type and description of each inspected and tested fire door assembly
10. Verification of visual inspection and functional operation
11. Listing of deficiencies in accordance with 5.2.3, Section 5.3, and Section 5.4

And the following shall be checked:

1. Labels are clearly visible and legible
2. No open holes or breaks exist in surfaces of either the door or frame
3. Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.
4. The door, frame, hinges, hardware, and non-combustible threshold are secured, aligned and in working order with no visible signs of damage
5. No parts are missing or broken
6. Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7
7. The self-closing device is operational; that is, the active door completely closes when operated from the full open position
8. If a coordinator is installed, the inactive lead close before the active lead

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Facility will need to identify and establish a schedule for inspection of Fire Doors. Annual inspection of fire doors will need to be performed and completed.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

At time of inspection the following was observed:

1. Horizontal fire-rated accordion type sliding doors in front of elevator in memory care area would not activate.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
9. Latching hardware operates and secures the door when it is in the closed position 10. Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame 11. No field modification to the door assembly have been performed that void the label. 12. Meeting edge protection, gasketing and edge seals where required, are inspected to verify their presence and intertie 13. Signage affixed to a door meets the requirements listed in 4.1.4	

Next inspection scheduled on or after: 10/28/2024

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

[Signature]
Signature

Sean McMahon Chief Engineer
Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2803 156 AVE SE
Bellevue WA 98007
(509) 406-7209

Jason E Van Gorkum
Signature



Washington State Patrol

Fire Protection Bureau

Phone: (360) 596-3900

Business Name Horizon House
Address 900 UNIVERSITY ST ,
City, State, Zip Seattle, WA 98101

Provider Number 000212
Approval Status Disapproved
Facility Type Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Time

Drills shall be held at unexpected times and under varying conditions to simulate the unusual conditions that occur in case of fire.

Exceptions:

1. In severe climates, the fire code official shall have the authority to modify the emergency evacuation drill termination points and frequency.
2. In Groups I-1, I-2, I-3 and R-4, where staff-only emergency evacuation drills are conducted after visiting hours or where care recipients are expected to be asleep, a coded announcement shall be an acceptable alternative to audible alarms.

(IFC 405.2 2021)

Records shall be maintained of required emergency evacuation drills and include the following information:

1. Identity of the person conducting the drill.
2. Date and time of the drill.
3. Notification method used.
4. Employees on duty and participating.
5. Number of occupants evacuated.
6. Special conditions simulated.
7. Problems encountered.
8. Weather conditions when occupants were evacuated.
9. Time required to accomplish complete evacuation.

(IFC 0405.6 2021)

Corrected

This document was prepared by Residential Care Services for the locator website.



Washington State Patrol

Fire Protection Bureau

Phone: (360) 596-3900

Business Name Horizon House
Address 900 UNIVERSITY ST ,
City, State, Zip Seattle, WA 98101

Provider Number 000212
Approval Status Disapproved
Facility Type Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

2 Application and Use

603.5.2 Application and use. Relocatable power taps and current taps shall be directly connected to a permanently installed receptacle.

Exceptions:

1. Where approved for use in a Group A occupancy or in a meeting room in a Group B occupancy, not more than five relocatable power taps shall be permitted to be connected together or connected to an extension cord for temporary use to supply power to electronic equipment.
2. Current taps and relocatable power taps shall not be required to connect directly to a permanently installed receptacle outlet where used for 90 days or less for the purpose of testing the performance of such devices.

(IFC 603.5.2, 2021)

At time of inspection the following was observed:

1. There was a power strip plugged into another power strip in memory care closets dining room.
2. multi extension cord found in use in hallway outside of office AL3

3 Cleaning

Hoods, grease-removal devices, fans, ducts and other appurtenances shall be cleaned at intervals as required by Sections 606.3.3.1 through 606.3.3.3.

(IFC 606.3.3 2021)

Corrected

4 Owner's Responsibility

The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space.

(IFC 701.6 2021)

At the time of inspection the following paperwork was not provided:

1. Facility will need to identify and establish a schedule for inspection of Fire-Rated construction. Annual inspection of fire-resistance-rated construction will need to be performed and completed.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
5 Door Operation	
Swinging fire doors shall close from the full-open position and latch automatically. (IFC 705.2.4 2021)	At time of inspection the following was observed: 1. Double doors by room 317 will not latch
6 Testing and Maintenance	
Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Corrected 1. Facility is working to resolve communication between fire pump and generator.
7 Extinguishing System Service	
Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion. (IFC 904.13.5.2 2021)	At time of Re-inspection the following was observed: 1. Deficiencies found on report. Facility is upgrading wet system to UL300.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
8 Portable Fire Extinguishers - General Requirements	
Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10. Exceptions: - The distance of travel to reach an extinguisher shall not apply. The travel distance to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies. - Thirty-day inspections shall not be required and maintenance shall be allowed to be once every three years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met: - Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed. - Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal. - The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment. - Electronic monitoring devices and supervisory circuits shall be tested every 3 years when extinguisher maintenance is performed. - A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10. - In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations. (IFC 906.2 2021)	At time of inspection the following was observed: Facility will need to perform an audit of fire extinguishers through building. A good number of fire extinguishers show that they have not been inspected since 2022.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Horizon House	Provider Number 000212
Address 900 UNIVERSITY ST ,	Approval Status Disapproved
City, State, Zip Seattle, WA 98101	Facility Type Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
9 Inspection, Testing and Maintenance	
The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	The following deficiencies were cited as a result of this inspection: At the time of inspection the following paperwork was not provided: 1. Annual report 2. Sensitivity Testing (IFC 907.8.3) 3. Monthly single and multiple station alarms test (IFC 907.8) All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected. At time of inspection the following was observed: 1. Communication part of the fire alarm system was in trouble
10 Carbon Monoxide Detection - General	
Carbon monoxide detection shall be installed in new buildings in accordance with Sections 915.1.1 through 915.6. Carbon monoxide detection shall be installed in existing buildings in accordance with Chapter 11 of the International Fire Code. (IFC 0915.1 2021 WAC 51-54A)	The following deficiencies were cited as a result of this inspection: At the time of inspection the following paperwork was not provided: 1. Carbon Monoxide Alarms and Detectors will need to be tested, maintained and documented on am monthly schedule. All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.
11 Emergeney Lighting Equipment Inspection and Testing	
Emergency lighting shall be maintained in accordance with Section 1008 and shall be inspected and tested in accordance with Sections 1031.10.1 and 1031.10.2. (IFC 1032.10 2021)	At time of inspection the following was observed: 1. Exit sign not working located out reverse door AL2

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Horizon House
Address 900 UNIVERSITY ST ,
City, State, Zip Seattle, WA 98101

Provider Number 000212
Approval Status Disapproved
Facility Type Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
12 Activation Test	
Emergency lighting equipment shall be tested monthly for a duration of not less than 30 seconds. The test shall be performed manually or by an automated self-testing and self-diagnostic routine. Where testing is performed by self-testing and self-diagnostics, a visual inspection of the emergency lighting equipment shall be conducted monthly to identify any equipment displaying a trouble indicator or that has become damaged or otherwise impaired. (IFC 1032.10.1 2021)	Corrected
13 Power Test	
Battery-powered emergency lighting equipment shall be tested annually by operating the equipment on battery power for not less than 90 minutes. (IFC 1031.10.2 2021)	Corrected
14 Maintenance	
Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	The following deficiencies were cited as a result of this inspection: At the time of inspection the following paperwork was not provided: 1. Annual service report 2. Log of weekly inspections 3. Monthly 30-minute full load test All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

This document was prepared by Residential Care Services for the Locator website



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
15 NFPA 80 Fire /Smoke Dampers Inspection and Testing	
19.4 Periodic Inspection and Testing. 19.4.1 Each damper shall be tested and inspected 1 year after installation. 19.4.1.1 The test and inspection frequency shall then be every 4 years, except in hospitals, where the frequency shall be every 6 years.	The following deficiencies were cited as a result of this inspection: At the time of inspection the following paperwork was not provided: 1. Fire/smoke damper inspection will need to be performed and documented All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Horizon House
Address 900 UNIVERSITY ST ,
City, State, Zip Seattle, WA 98101

Provider Number 000212
Approval Status Disapproved
Facility Type Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

16 NFPA 80 Fire Door Inspection and Testing

5.2.1 Inspection and Testing. Upon completion of the installation, door, shutters, and window assemblies shall be inspected and tested in accordance with 5.2.4.

5.2.4 Periodic Inspection and Testing.

5.2.4.1 Periodic inspections and testing shall be performed not less than annually.

5.2.2.4 A record of all inspections and testing shall be provided that includes, but is not limited to, the following information:

1. Date of inspection
2. Name of facility
3. Address of facility
4. Name of person(s) performing inspections and testing
5. Company name and address of inspecting company
6. Signature of inspector of record
7. Individual record of each inspected and tested fire door assembly
8. Opening identifier and location of each inspected and tested fire door assembly
9. Type and description of each inspected and tested fire door assembly
10. Verification of visual inspection and functional operation
11. Listing of deficiencies in accordance with 5.2.3, Section 5.3, and Section 5.4

And the following shall be checked:

1. Labels are clearly visible and legible
2. No open holes or breaks exist in surfaces of wither the door or frame
3. Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.
4. The door, frame, hinges, hardware, and non combustible threshold are secured, aligned and in working order with no visible, signs of damage
5. No parts are missing or broken
6. Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7
7. The self-closing device is operational; that is, the active door completely closes when operated from the full open position
8. If a coordinator is installed, the inactive lead close before the active lead

The following deficiencies were cited as a result of this inspection:

At the time of inspection the following paperwork was not provided:

1. Facility will need to identify and establish a schedule for inspection of Fire Doors. Annual inspection of fire doors will need to be performed and completed.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

At time of inspection the following was observed:

1. Horizontal fire-rated accordion type sliding doors in front of elevator in memory care area would not activate.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Horizon House	Provider Number	000212
Address	900 UNIVERSITY ST ,	Approval Status	Disapproved
City, State, Zip	Seattle, WA 98101	Facility Type	Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
9. Latching hardware operates and secures the door when it is in the closed position 10. Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame 11. No field modification to the door assembly have been preformed that void the label. 12. Meeting edge protection, gasketing and edge seals where required, are inspected to verify their presence and intertie 13. Signage affixed to a door meets the requirements listed in 4.1.4	

Next inspection scheduled on or after: 10/28/2024


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Sean McMahan Chief Engineer
Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2803 156 AVE SE
Bellevue WA 98007
(509) 406-7209


Signature