



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	El Dorado West Retirement Community	Provider Number	2140
Address	1010 SW 134TH ST ,	Approval Status	Approved
City, State, Zip	Burien, WA 98146	Facility Type	Residential Care

On 10/09/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 150033 Here's a complaint of fire alarm Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? None 2. If the sprinklers were activated? No 3. If there was an evacuation / how many were evacuated? 0 4. If there were injuries / how many? 0 5. Did the fire department respond? Yes	On October 09, 2024, DSFM Christian entered El Dorado West Retirement Community located at 1010 SW 134th St, Burien WA 98223 to investigate complaint ref # 150033. I interview the Maintenance Director about the fire alarm that triggered. On October 6 and 7, 2024 the fire alarm went off at the facility. The panel showed a sprinkler system failure. The fire department responded, made sure there was no fire and then silenced the alarm. The facility contacted their contractor who came out and inspected the dry sprinkler system. The contractor stated the accelerator failed. The fire system is up and running normal. The facility conducted a fire watch of every 15 minutes until they were told everything was working properly. No IFC violations observed
--	---

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

AVDIC SEMKO
Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796

Signature