



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Easthaven Villa	Provider Number	002144
Address	311 Cullins RD NW,	Approval Status	Approved
City, State, Zip	Yelm, WA 98597	Facility Type	Residential Care

On 07/30/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 139806

Here's a complaint of fire panel down

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

COMPLAINT # 139806

A complaint investigation was conducted at Easthaven Villa located at 311 Cullens Street NW, Yelm, WA 98597.

An interview was conducted with facility staff. Fire alarm panel in memory care was not connecting to monitoring company. Fire alarm panel has been fixed and in normal status.

There were no signs of a fire, the sprinkler system was not activated, there were no evacuations, there were no injuries and the fire department did not respond.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

NOT AVAILABLE.
Signature

Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Signature