



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cottages at Marysville, The	Provider Number	2149
Address	1216 Grove ST ,	Approval Status	Approved
City, State, Zip	Marysville, WA 98207	Facility Type	Residential Care

On 06/13/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 84397 Here's a complaint of fire panel malfunction Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	Complaint ref # 84397 At 1500 on the 06/13/23, DSFM Brown entered The Cottages at Marysville located at 1216 Grove St, Marysville, WA 98270 to investigate complaint ref# 84397. On 6/5/31/23 at 1300 the fire alarm panel stopped working and the facility entered fire watch. The vendor attempted to replace the panel, but the new system would not integrate with the old detectors. The broken panel was shipped to Florida for repair. On 6/7/23 the panel was re-installed and tested. No injuries were report. No violations observed.
--	--

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature _____ Print Name and Title _____

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

Brandon G. Brown Digitally signed by Brandon G. Brown
Date: 2023.06.13 16:04:03 -07'00'
Signature _____

This document was prepared by Residential Care Services for the Locator website.