



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cottages at Marysville, The	Provider Number	2149
Address	1216 Grove ST,	Approval Status	Approved
City, State, Zip	Marysville, WA 98207	Facility Type	Residential Care

On 08/28/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner, or Owner's Representative

Shawn A. Sparks
Signature

Shawn A. Sparks Maint. Supervisor
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

[Signature]
Signature

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cottages at Marysville, The	Provider Number	2149
Address	1216 Grove ST ,	Approval Status	Disapproved
City, State, Zip	Marysville, WA 98207	Facility Type	Residential Care

On 07/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Owner's Responsibility

The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space.

(IFC 701.6 2018 WAC 51-54A)

Facility is unable to provide documentation that the annual fire resistance rated construction material inspection has been completed.

2 Duct and Air Transfer Openings - Maintaining Protection

Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced.

(IFC 706.1 2018)

Facility is unable to provide documentation for the 4 year fire and smoke damper inspection.

3 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

1. Facility is unable to provide documentation for the annual forward flow test in accordance with NFPA 25.

2. Facility is unable to provide documentation for the quarterly sprinkler system inspections.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cottages at Marysville, The	Provider Number	2149
Address	1216 Grove ST ,	Approval Status	Disapproved
City, State, Zip	Marysville, WA 98207	Facility Type	Residential Care

On 07/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 08/23/2024

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Shawn A. Sparks
Signature

Shawn A. Sparks Maint. Sup.
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

[Signature]
Signature

Initials of Authorized Facility Representative: _____