




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900


Business Name	Ovenell Home ALF Inc	Provider Number	2172
Address	625 Washington ,	Approval Status	Approved
City, State, Zip	Burlington, WA 98233	Facility Type	Residential Care

On 06/20/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature


Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

Brandon G. Brown

Digitally signed by Brandon G.
Brown
Date: 2023.06.20 15:16:46 -07'00'

Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Ovenell Home ALF Inc	Provider Number 2172
Address 625 Washington ,	Approval Status Disapproved
City, State, Zip Burlington, WA 98233	Facility Type Residential Care

On 06/12/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Multiplug Adapters

Multiplug adapters, such as cube adapters, unfused plug strips or any other device not complying with NFPA 70 shall be prohibited.

(IFC 604.4 2018)

The following violations were observed:

There was multi-plug adapter that does not have over current protection in use in the kitchen.

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2009, 2012, 2015, 2018)

The following violations were observed:

1. Facility is unable to provide documentation for the annual sprinkler system inspection.
2. Facility is unable to provide documentation for the quarterly sprinkler system inspections.

3 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2018)

The following violations were observed:

Facility is unable to provide documentation for the annual fire alarm system testing.

4 Power Test

Battery-powered emergency lighting equipment shall be tested annually by operating the equipment on battery power for not less than 90 minutes.

(IFC 1031.10.2 2018)

The following violations were observed:

Facility is unable to provide documentation for the annual 90 minute power test for the emergency lights.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Ovenell Home ALF Inc
Address 625 Washington ,
City, State, Zip Burlington, WA 98233

Provider Number 2172
Approval Status Disapproved
Facility Type Residential Care

On 06/12/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
5 Fire Drills In all Group I, Group E, and Group R2 Occupancies licensed by the state and inspected by the state fire marshal's office, at least twelve planned and unannounced fire drills shall be held every year. (1) Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. (2) A detailed written record of all fire drills shall be maintained and available for inspection. (3) When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms.	The following violations were observed: 1. Facility cannot provide documentation for the completion of twelve planned and unannounced fire drills in the previous 12 months. 2. Facility is simulating the fire alarm during day and swing shifts. 3. Participation lists do not include all staff on duty.

Next inspection scheduled on or after: 07/12/2023

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037

Signature

Initials of Authorized Facility Representative: _____