



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Liberty Place	Provider Number	2182
Address	155 LIPPERT ,	Approval Status	Disapproved
City, State, Zip	Port Orchard, WA	Facility Type	Residential Care

On 03/17/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Findings during the inspection were:

Kitchen area has multiple sprinkler heads that are loaded with debris.

2 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

Findings during the inspection were:


Electrical panel did not have lock on the fire alarm electrical breaker.

Next inspection scheduled on or after: 05/31/2027


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature


Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0667


Signature