



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Victoria Place	Provider Number	2185
Address	491 DISCOVERY RD ,	Approval Status	Approved
City, State, Zip	Port Townsend, WA 98368	Facility Type	Residential Care

On 02/19/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # broken pipes

Here's a complaint of 167159

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? No fire.
2. If the sprinklers were activated? No.
3. If there was an evacuation / how many were evacuated? No.
4. If there were injuries / how many? No.
5. Did the fire department respond? Yes.

COMPLAINT # 167159

On February 19th, 2025 a complaint investigation was conducted at Victoria Place located at 491 Discovery Road, Port Townsend, WA.


An interview was conducted with facility staff. Sprinkler pipe in residential hallway broke on 2/8/25, facility started fire watch until system was fixed. On 2/12/25 a remediation worker stepped on sprinkler pipe which set off the system again and facility started fire watch again. Sprinkler system and fire alarm system are in normal status.

There was no fire, the sprinkler system went off and fire alarm activated, there were no injuries, and fire department did respond.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature 

Print Name and Title Jennifer Huntley, Executive Director

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Raul Murcia

Digitally signed by Raul Murcia
Date: 2025.02.20 10:40:28
+08'00'

Signature