



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Victoria Place	Provider Number	2185
Address	491 DISCOVERY RD ,	Approval Status	Approved
City, State, Zip	Port Townsend, WA	Facility Type	Residential Care

On 08/28/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 191152

Here's a complaint of Fire

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

COMPLAINT # 191152

On 8/28/25 a complaint investigation was conducted at Victoria Place located at 491 Discovery Road, Port Townsend, WA 98368.

An interview was conducted with facility staff. A fire started in a field in the back of the building by a lithium bike battery. Fire department responded and evacuated the building. Spoke with staff about following their emergency plan book.

The sprinkler system did not activate, there were no injuries and the fire department did respond.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

NOT AVAILABLE
Signature

Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Signature