



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900


Business Name Scriber Gardens LLC
Address 6024 200 ST SW,
City, State, Zip Lynnwood, WA

Provider Number 2203
Approval Status Approved
Facility Type Residential Care

On 02/12/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

Leslie Young Wellness Director
Print Name and Title

Deputy State Fire Marshal Jason Van Gorkum
2502 112 ST E
Tacoma WA 984455104
(509) 406-7209


Signature

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Scriber Gardens LLC	Provider Number	2203
Address	6024 200 ST SW,	Approval Status	Disapproved
City, State, Zip	Lynnwood, WA	Facility Type	Residential Care

On 11/25/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Cleaning

Hoods, grease-removal devices, fans, ducts and other appurtenances shall be cleaned at intervals as required by Sections 606.3.3.1 through 606.3.3.3.

(IFC 606.3.3 2021)

Corrected

2 Door Operation

Swinging fire doors shall close from the full-open position and latch automatically.

(IFC 705.2.4 2021)

Corrected

3 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.

(IFC 904.13.5.2 2021)

Findings during the inspection were:

Facility is unable to provide documentation for the semi-annual kitchen suppression system servicing.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

9/11/2025

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Scriber Gardens LLC

Provider Number 2203

Address 6024 200 ST SW,

Approval Status Disapproved

City, State, Zip Lynnwood, WA

Facility Type Residential Care

On 11/25/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 12/26/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative



Signature

EMIL KAZIC MAINTENANCE
Print Name and Title

Deputy State Fire Marshal ~~Damon Roberson~~
2803 156 AVE SE
Bellevue WA 98007
(360) 584-4392

Jason Van Gorkum

Signature



This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

This document was prepared by Residential Care Services for the Locator website.

Business Name Scriber Gardens LLC

Provider Number 2203

Address 6024 200 ST SW,

Approval Status Disapproved

City, State, Zip Lynnwood, WA

Facility Type Residential Care

On 08/26/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Cleaning

Hoods, grease-removal devices, fans, ducts and other appurtenances shall be cleaned at intervals as required by Sections 606.3.3.1 through 606.3.3.3.

(IFC 606.3.3 2021)

Facility is unable to provide documentation for the semi-annual hood cleaning.

2 Door Operation

Swinging fire doors shall close from the full-open position and latch automatically.

(IFC 705.2.4 2021)

Throughout the facility a number of fire and smoke doors were found propped open.

3 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.

(IFC 904.13.5.2 2021)

Facility is unable to provide documentation for the semi-annual kitchen suppression system servicing.

Next inspection scheduled on or after: 09/25/2025


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

EMIR KATIC MAINTENANCE
Print Name and Title

Deputy State Fire Marshal Arthur ~~Jesse Ward~~ Jesse VanCort
2502 112 ST E
Tacoma WA 984455104
(425) 401-7735


Signature