




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Light House Memory Care	Provider Number	2204
Address	3502 K AVE ,	Approval Status	Approved
City, State, Zip	Anacortes, WA 98221	Facility Type	Residential Care

On 07/12/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

Jessica Trumble Executive Director
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037


Signature

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Light House Memory Care	Provider Number 2204
Address 3502 K AVE ,	Approval Status Disapproved
City, State, Zip Anacortes, WA 98221	Facility Type Residential Care

On 06/08/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
1 Power Supply	
Relocatable power taps shall be directly connected to a permanently installed receptacle. (IFC 604.4.2 2018)	The following violations were observed: There is a power strip plugged into an extension cord into another power strip in the maintenance office.
2 Extension Cords	
Extension cords and flexible cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors. (IFC 604.5 2018)	The following violations were observed: There was an extension cord utilized as permanent wiring in the beauty salon.
3 Cleaning	
Hoods, grease-removal devices, fans, ducts and other appurtenances shall be cleaned at intervals as required by Sections 607.3.3.1 through 607.3.3.3. (IFC 607.3.3 2018)	The following violations were observed: Facility is unable to provide documentation for the semi-annual hood cleaning.
4 Duct and Air Transfer Openings - Maintaining Protection	
Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced. (IFC 706.1 2018)	The following violations were observed: Facility is unable to provide documentation for the 4 year fire and smoke damper inspection.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Light House Memory Care	Provider Number 2204
Address 3502 K AVE ,	Approval Status Disapproved
City, State, Zip Anacortes, WA 98221	Facility Type Residential Care

On 06/08/2023 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

5 Fire Drills

In all Group I, Group E, and Group R2 Occupancies licensed by the state and inspected by the state fire marshal's office, at least twelve planned and unannounced fire drills shall be held every year.

(1) Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions.

(2) A detailed written record of all fire drills shall be maintained and available for inspection.

(3) When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms.

The following violations were observed:

Facility cannot provide documentation for the completion of twelve planned and unannounced fire drills in the previous 12 months.

The following Drills are missing.

1st Shift - Quarter 1, 2, and 3
2nd Shift - Quarter 1, 2, 3, and 4
3rd Shift - Quarter 2, 3, and 4

Next inspection scheduled on or after: 07/08/2023

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Jessica Trumble Executive Director
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
16778 146 ST SE
Monroe WA 98272
(360) 791-7037


Signature