



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Ridge an Encore Community (The)
Address 1501 TOWER VIEW CIR NW,
City, State, Zip Silverdale, WA 98383

Provider Number 2231
Approval Status Approved
Facility Type Residential Care

On 05/08/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 174651

Here's a complaint of Fire watch

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

COMPLAINT # 174651

On 5/8/2025 a complaint investigation was conducted at The Ridge an Encore Community located at 1501 NW Tower View Circle, Silverdale WA, 98383.

An interview was conducted with facility staff. Facility was upgrading their phone lines and fire alarm system phone lines were updated by mistake. Fire alarm system was still operational but would not dial out to monitoring company. Facility implemented a fire watch until system was back to normal status. System in normal status.

There was no fire, the sprinkler system was not activated, the fire department did not respond, there were no evacuations, and there were no injuries.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

NOT AVAILABLE

Signature

Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Signature