




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Prestige Senior Living Auburn Meadows	Provider Number	2239
Address	945 22ND ST NE,	Approval Status	Approved
City, State, Zip	Auburn, WA 98002	Facility Type	Residential Care

On 10/20/2025 the Office of the State Fire Marshal conducted an inspection at your facility.


All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

James W Heipel
Print Name and Title

Deputy State Fire Marshal Alan Harlan
2803 156TH AVE SE
Bellevue WA 98007
(425) 495-7121


Signature

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Prestige Senior Living Auburn Meadows	Provider Number	2239
Address	945 22ND ST NE,	Approval Status	Disapproved
City, State, Zip	Auburn, WA 98002	Facility Type	Residential Care

On 8/7/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Administration

On 08/07/2025 an unannounced Fire and Life Safety Code re-inspection was conducted at Prestige Senior Living Auburn Meadows by a representative of the Washington State Patrol, State Fire Marshal's Office to determine compliance with all applicable codes.

The following deficiencies were cited as a result of this re-inspection:

2 Duct and Air Transfer Openings - Maintaining Protection

Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced.

(IFC 706.1 2018)

3 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

The following violation was observed at time of re-inspection:

The facility was unable to provide fire alarm correction report. The fire alarm is currently in trouble status.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Prestige Senior Living Auburn Meadows	Provider Number	2239
Address	945 22ND ST NE,	Approval Status	Disapproved
City, State, Zip	Auburn, WA 98002	Facility Type	Residential Care

On 8/7/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 9/6/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

James Harper Maint Director
Print Name and Title

Deputy State Fire Marshal Alan Harlan
2803 156TH AVE SE
Bellevue WA 98007
(425) 495-7121


Signature



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Prestige Senior Living Auburn Meadows	Provider Number	2239
Address	945 22ND ST NE,	Approval Status	Disapproved
City, State, Zip	Auburn, WA 98002	Facility Type	Residential Care

On 06/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Administration

On 6/03/2025 an unannounced Fire and Life Safety Code re-inspection was conducted at Prestige Senior Living Auburn Meadows by a representative of the Washington State Patrol, State Fire Marshal's Office to determine compliance with all applicable codes.

The following deficiencies were cited as a result of this re-inspection:

30 day extension to install forward flow equipment - approved 3/3/2025

2 Ash Trays

Where smoking is permitted, suitable noncombustible ash trays or match receivers shall be provided on each table and at other appropriate locations. In Group I-2 occupancies, noncombustible metal containers with self-closing covers shall be provided in areas where smoking is permitted

(IFC 310.6 2021)

Corrected



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Prestige Senior Living Auburn Meadows
Address 945 22ND ST NE,
City, State, Zip Auburn, WA 98002

Provider Number 2239
Approval Status Disapproved
Facility Type Residential Care

On 06/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

3 Fire Safety Plans

Fire safety plans shall include the following:

1. The procedure for reporting a fire or other emergency.
2. The life safety strategy including the following:
 - 2.1. Procedures for notifying occupants, including areas with a private mode alarm system.
 - 2.2. Procedures for occupants under a defend-in-place response.
 - 2.3. Procedures for evacuating occupants, including those who need evacuation assistance.
3. Site plans indicating the following:
 - 3.1. The occupancy assembly point.
 - 3.2. The locations of fire hydrants.
 - 3.3. The normal routes of fire department vehicle access.
4. Floor plans identifying the locations of the following:
 - 4.1. Exits.
 - 4.2. Primary evacuation routes.
 - 4.3. Secondary evacuation routes.
 - 4.4. Accessible egress routes.
 - 4.4.1. Areas of refuge.
 - 4.4.2. Exterior areas for assisted rescue.
 - 4.5. Refuge areas associated with smoke barriers and horizontal exits.
 - 4.6. Manual fire alarm boxes.
 - 4.7. Portable fire extinguishers.
 - 4.8. Occupant-use hose stations.
 - 4.9. Fire alarm annunciators and controls.
5. A list of major fire hazards associated with the normal use and occupancy of the premises, including maintenance and housekeeping procedures.
6. Identification and assignment of personnel responsible for maintenance of systems and equipment installed to prevent or control fires.
7. Identification and assignment of personnel responsible for maintenance, housekeeping and controlling fuel hazard sources.

Corrected



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Prestige Senior Living Auburn Meadows	Provider Number	2239
Address	945 22ND ST NE,	Approval Status	Disapproved
City, State, Zip	Auburn, WA 98002	Facility Type	Residential Care

On 06/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

(IFC 404.2.2 2021)

4 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors..

Corrected

(IFC 603.6 2021)

5 Penetrations - Maintaining Protection

Materials and firestop systems used to protect membrane and through penetrations in fire-resistance-rated construction and construction installed to resist the passage of smoke shall be maintained. The materials and firestop systems shall be securely attached to or bonded to the construction being penetrated with no openings visible through or into the cavity of the construction. Where the system design number is known, the system shall be inspected to the listing criteria and manufacturer's installation instructions.

Corrected

(IFC 703.1 2021)

6 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified.

Corrected

(IFC 705.2 2021)



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Prestige Senior Living Auburn Meadows	Provider Number	2239
Address	945 22ND ST NE,	Approval Status	Disapproved
City, State, Zip	Auburn, WA 98002	Facility Type	Residential Care

On 06/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

7 Duct and Air Transfer Openings - Maintaining Protection

Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced.

(IFC 706.1 2018)

The following violation was observed at the time of re-inspection:

The facility was unable to provide documentation for their repairs on their last fire/smoke damper testing.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected

Scheduled 2/21



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Prestige Senior Living Auburn Meadows

Provider Number 2239

Address 945 22ND ST NE,

Approval Status Disapproved

City, State, Zip Auburn, WA 98002

Facility Type Residential Care

On 06/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

8 Combustible Decorative Materials

In Groups A, B, E, I, M and R-1 and in dormitories in Group R-2, curtains, draperies, fabric hangings and other similar combustible decorative materials suspended from walls or ceilings shall comply with Section 807.3 and shall not exceed 10 percent of the specific wall or ceiling area to which such materials are attached. Fixed or movable walls and partitions, paneling, wall pads and crash pads applied structurally or for decoration, acoustical correction, surface insulation or other purposes shall be considered to be interior finish, shall comply with Section 803 and shall not be considered decorative materials or furnishings.

Exceptions:

1. In auditoriums in Group A, the permissible amount of curtains, draperies, fabric hangings and similar combustible decorative material suspended from walls or ceilings shall not exceed 75 percent of the aggregate wall area where the building is equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1, and where the material is installed in accordance with Section 803.15 of the International Building Code.
2. In Group R-2 dormitories, within sleeping units and dwelling units, the permissible amount of curtains, draperies, fabric hangings and similar decorative materials suspended from walls or ceilings shall not exceed 50 percent of the aggregate wall areas where the building is equipped throughout with an approved automatic sprinkler system installed in accordance with Section 903.3.1.
3. In Group B and M occupancies, the amount of combustible fabric partitions suspended from the ceiling and not supported by the floor shall comply with Section 807.3 and shall not be limited.
4. The 10-percent limit shall not apply to curtains, draperies, fabric hangings and similar combustible decorative materials used as window coverings.

(IFC 807.2 2018)

Corrected



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Prestige Senior Living Auburn Meadows	Provider Number	2239
Address	945 22ND ST NE,	Approval Status	Disapproved
City, State, Zip	Auburn, WA 98002	Facility Type	Residential Care

On 06/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

9 Inspection, Testing and Maintenance

Fire protection and life safety systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection and life safety systems and equipment shall be inspected, tested and maintained or removed in accordance with Section 901.8.

(IFC 901.6 2021)

Corrected

10 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2009, 2012, 2015, 2018)

Corrected

11 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.

(IFC 904.13.5.2 2021)

Corrected



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Prestige Senior Living Auburn Meadows	Provider Number	2239
Address	945 22ND ST NE,	Approval Status	Disapproved
City, State, Zip	Auburn, WA 98002	Facility Type	Residential Care

On 06/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

12 Portable Fire Extinguishers - General Requirements

Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Exceptions:

1. The distance of travel to reach an extinguisher shall not apply. The travel distance to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies.
2. Thirty-day inspections shall not be required and maintenance shall be allowed to be once every three years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met:
 - 2.1. Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed.
 - 2.2. Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal.
 - 2.3. The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment.
 - 2.4. Electronic monitoring devices and supervisory circuits shall be tested every 3 years when extinguisher maintenance is performed.
 - 2.5. A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10.
3. In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations.

(IFC 906.2 2021)

Corrected

13 Hangers and Brackets

Hand-held portable fire extinguishers, not housed in cabinets, shall be installed on the hangers or brackets supplied. Hangers or brackets shall be securely anchored to the mounting surface in accordance with the manufacturer's installation instructions.

(IFC 906.7 2021)

Corrected



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Prestige Senior Living Auburn Meadows	Provider Number	2239
Address	945 22ND ST NE,	Approval Status	Disapproved
City, State, Zip	Auburn, WA 98002	Facility Type	Residential Care

On 06/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

14 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

The following violation was observed at the time of re-inspection:

The facility was unable to provide record of their annual inspection for their fire alarm system.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

15 Maintenance

Carbon monoxide alarms and carbon monoxide detection systems shall be maintained in accordance with NFPA 72. Carbon monoxide alarms and carbon monoxide detectors that become inoperable or begin producing end-of-life signals shall be replaced.

(IFC 915.6 2021 WAC)

Corrected

16 Internally Illuminated Exit Signs

Electrically powered, self-luminous and photoluminescent exit signs shall be listed and labeled in accordance with UL 924 and shall be installed in accordance with the manufacturer's instructions and Section 1203. Exit signs shall be illuminated at all times.

(IFC 1013.5 2021)

Corrected

17 Reliability

Required exit accesses, exits and exit discharges shall be continuously maintained free from obstructions or impediments to full instant use in the case of fire or other emergency when the building area served by the means of egress is occupied. An exit or exit passageway shall not be used for any purpose that interferes with a means of egress.

(IFC 1032.2 2021)

Corrected



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Prestige Senior Living Auburn Meadows	Provider Number	2239
Address	945 22ND ST NE,	Approval Status	Disapproved
City, State, Zip	Auburn, WA 98002	Facility Type	Residential Care

On 06/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
18 Maintenance	
Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	Corrected
19 Fire Drills	
In all Group I, Group E, and Group R2 Occupancies licensed by the state, at least twelve planned and unannounced fire drills shall be held every year. Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. A detailed written record of all fire drills shall be maintained and available for inspection at all times. When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms. Fire drills shall include the transmission of a fire alarm signal and simulation of emergency conditions. The fire alarm monitoring company shall be notified prior to the activation of the fire alarm system for drill purposes and again at the conclusion of the transmission and restoration of the fire alarm system to normal mode. (WAC 212-12-044)	Corrected

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Prestige Senior Living Auburn Meadows	Provider Number	2239
Address	945 22ND ST NE,	Approval Status	Disapproved
City, State, Zip	Auburn, WA 98002	Facility Type	Residential Care

On 06/03/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature


Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796


Signature



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Prestige Senior Living Auburn Meadows
Address 945 22ND ST NE,
City, State, Zip Auburn, WA 98002

Provider Number 2239
Approval Status Disapproved
Facility Type Residential Care

On 12/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Administration

On 12/24/2024 an unannounced Fire and Life Safety Code inspection was conducted at Prestige Senior Living Auburn Meadows by a representative of the Washington State Patrol, State Fire Marshal's Office to determine compliance with all applicable codes.

The following deficiencies were cited as a result of this inspection:

Note:

Facility will need to look at their evacuation routes and determine if the delayed egress doors in memory care are to be used as exits. If so; the facility will need to add an exit sign to each door dedicated for exit usage.

It is unclear at this time as there are no evacuation routes posted.

Note:

The facility has newly installed battery operated emergency lighting in the kitchen which will need to start being tested 30 seconds every month, and annually for 90 minutes.

2 Ash Trays

Where smoking is permitted, suitable noncombustible ash trays or match receivers shall be provided on each table and at other appropriate locations. In Group I-2 occupancies, noncombustible metal containers with self-closing covers shall be provided in areas where smoking is permitted

(IFC 310.6 2021)

The following violation was observed at the time of inspection:

The facility has a plastic liner in their ashtrays outside. Cigarette butts have been placed in the plastic liner.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Prestige Senior Living Auburn Meadows
Address 945 22ND ST NE,
City, State, Zip Auburn, WA 98002

Provider Number 2239
Approval Status Disapproved
Facility Type Residential Care

On 12/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

3 Fire Safety Plans

Fire safety plans shall include the following:

1. The procedure for reporting a fire or other emergency.
2. The life safety strategy including the following:
 - 2.1. Procedures for notifying occupants, including areas with a private mode alarm system.
 - 2.2. Procedures for occupants under a defend-in-place response.
 - 2.3. Procedures for evacuating occupants, including those who need evacuation assistance.
3. Site plans indicating the following:
 - 3.1. The occupancy assembly point.
 - 3.2. The locations of fire hydrants.
 - 3.3. The normal routes of fire department vehicle access.
4. Floor plans identifying the locations of the following:
 - 4.1. Exits.
 - 4.2. Primary evacuation routes.
 - 4.3. Secondary evacuation routes.
 - 4.4. Accessible egress routes.
 - 4.4.1. Areas of refuge.
 - 4.4.2. Exterior areas for assisted rescue.
 - 4.5. Refuge areas associated with smoke barriers and horizontal exits.
 - 4.6. Manual fire alarm boxes.
 - 4.7. Portable fire extinguishers.
 - 4.8. Occupant-use hose stations.
 - 4.9. Fire alarm annunciators and controls.
5. A list of major fire hazards associated with the normal use and occupancy of the premises, including maintenance and housekeeping procedures.
6. Identification and assignment of personnel responsible for maintenance of systems and equipment installed to prevent or control fires.
7. Identification and assignment of personnel responsible for maintenance, housekeeping and controlling fuel hazard sources.

The following violation was observed at the time of inspection:

The facility does not have evacuation routes posted.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Prestige Senior Living Auburn Meadows
Address 945 22ND ST NE,
City, State, Zip Auburn, WA 98002

Provider Number 2239
Approval Status Disapproved
Facility Type Residential Care

On 12/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

(IFC 404.2.2 2021)

4 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors..

(IFC 603.6 2021)

The following violation was observed at the time of inspection:

The following locations have extension cords in use:

1. Resident room 203
2. Resident room 233
3. Resident room 120

5 Penetrations - Maintaining Protection

Materials and firestop systems used to protect membrane and through penetrations in fire-resistance-rated construction and construction installed to resist the passage of smoke shall be maintained. The materials and firestop systems shall be securely attached to or bonded to the construction being penetrated with no openings visible through or into the cavity of the construction. Where the system design number is known, the system shall be inspected to the listing criteria and manufacturer's installation instructions.

(IFC 703.1 2021)

The following violation was observed at the time of inspection:

The dining room has a penetration in the wall. - by the exit doors in the corner

6 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified.

(IFC 705.2 2021)

The following violation was observed at the time of inspection:

The following doors did not close / latch properly when tested:

1. Laundry door 32 - 2nd floor
2. Resident room 250



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Prestige Senior Living Auburn Meadows	Provider Number	2239
Address	945 22ND ST NE,	Approval Status	Disapproved
City, State, Zip	Auburn, WA 98002	Facility Type	Residential Care

On 12/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

7 Duct and Air Transfer Openings - Maintaining Protection

Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced.

(IFC 706.1 2018)

The following violation was observed at the time of inspection:

The facility was unable to provide documentation for their last fire/smoke damper testing.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau

Phone: (360) 596-3900

Business Name Prestige Senior Living Auburn Meadows
Address 945 22ND ST NE,
City, State, Zip Auburn, WA 98002

Provider Number 2239
Approval Status Disapproved
Facility Type Residential Care

On 12/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

8 Combustible Decorative Materials

In Groups A, B, E, I, M and R-1 and in dormitories in Group R-2, curtains, draperies, fabric hangings and other similar combustible decorative materials suspended from walls or ceilings shall comply with Section 807.3 and shall not exceed 10 percent of the specific wall or ceiling area to which such materials are attached. Fixed or movable walls and partitions, paneling, wall pads and crash pads applied structurally or for decoration, acoustical correction, surface insulation or other purposes shall be considered to be interior finish, shall comply with Section 803 and shall not be considered decorative materials or furnishings.

Exceptions:

1. In auditoriums in Group A, the permissible amount of curtains, draperies, fabric hangings and similar combustible decorative material suspended from walls or ceilings shall not exceed 75 percent of the aggregate wall area where the building is equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1, and where the material is installed in accordance with Section 803.15 of the International Building Code.
2. In Group R-2 dormitories, within sleeping units and dwelling units, the permissible amount of curtains, draperies, fabric hangings and similar decorative materials suspended from walls or ceilings shall not exceed 50 percent of the aggregate wall areas where the building is equipped throughout with an approved automatic sprinkler system installed in accordance with Section 903.3.1.
3. In Group B and M occupancies, the amount of combustible fabric partitions suspended from the ceiling and not supported by the floor shall comply with Section 807.3 and shall not be limited.
4. The 10-percent limit shall not apply to curtains, draperies, fabric hangings and similar combustible decorative materials used as window coverings.

(IFC 807.2 2018)

The following violation was observed at the time of inspection:

Resident room 309 in memory care has combustible wall paper covering the entire wall.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau

Phone: (360) 596-3900

Business Name Prestige Senior Living Auburn Meadows
Address 945 22ND ST NE,
City, State, Zip Auburn, WA 98002

Provider Number 2239
Approval Status Disapproved
Facility Type Residential Care

On 12/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

9 Inspection, Testing and Maintenance

Fire protection and life safety systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection and life safety systems and equipment shall be inspected, tested and maintained or removed in accordance with Section 901.8.

(IFC 901.6 2021)

The following violation was observed at the time of inspection:

The following locations have escutcheon rings missing:

1. Lobby by reception area - by window
2. Resident room 258 - back room
3. Resident room 214

The Laundry on the 2nd floor has loaded sprinkler heads. - by TV / Library room

10 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2009, 2012, 2015, 2018)

The following violation was observed at the time of inspection:

The facility was unable to provide documentation for:

1. 5 year internal pipe inspection
2. Forward Flow test
3. 2nd and 4th quarter sprinkler inspection

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

11 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.

(IFC 904.13.5.2 2021)

The following violation was observed at the time of inspection:

The facility was unable to provide service reports showing that the kitchen suppression system has been serviced semi-annually in the past 12 months.

Facility stated the kitchen just reopened from the remodel, however unable to provide sign off documents.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.



Washington State Patrol
Fire Protection Bureau

Phone: (360) 596-3900

Business Name Prestige Senior Living Auburn Meadows

Address 945 22ND ST NE,

City, State, Zip Auburn, WA 98002

Provider Number 2239

Approval Status Disapproved

Facility Type Residential Care

On 12/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

12 Portable Fire Extinguishers - General Requirements

Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Exceptions:

1. The distance of travel to reach an extinguisher shall not apply. The travel distance to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies.

2. Thirty-day inspections shall not be required and maintenance shall be allowed to be once every three years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met:

2.1. Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed.

2.2. Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal.

2.3. The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment.

2.4. Electronic monitoring devices and supervisory circuits shall be tested every 3 years when extinguisher maintenance is performed.

2.5. A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10.

3. In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations.

(IFC 906.2 2021)

The following violation was observed at the time of inspection:

The facility has a fire extinguisher in memory care that has not been completed in accordance with NFPA 10 - by 301

13 Hangers and Brackets

Hand-held portable fire extinguishers, not housed in cabinets, shall be installed on the hangers or brackets supplied. Hangers or brackets shall be securely anchored to the mounting surface in accordance with the manufacturer's installation instructions.

(IFC 906.7 2021)

The following violation was observed at the time of inspection:

The fire extinguisher in the Mechanical room is not mounted. Facility stated it had not been serviced. - by room 250



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Prestige Senior Living Auburn Meadows	Provider Number	2239
Address	945 22ND ST NE,	Approval Status	Disapproved
City, State, Zip	Auburn, WA 98002	Facility Type	Residential Care

On 12/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

14 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

The following violation was observed at the time of inspection:

The facility was unable to provide record of their annual inspection for their fire alarm system.

All inspection reports must verify that the system has no deficiencies, or document that all deficiencies have been corrected.

15 Maintenance

Carbon monoxide alarms and carbon monoxide detection systems shall be maintained in accordance with NFPA 72. Carbon monoxide alarms and carbon monoxide detectors that become inoperable or begin producing end-of-life signals shall be replaced.

(IFC 915.6 2021 WAC)

The following violation was observed at the time of inspection:

The facility was unable to provide documentation showing that monthly testing of their CO detectors have been performed in the past 12 months.

16 Internally Illuminated Exit Signs

Electrically powered, self-luminous and photoluminescent exit signs shall be listed and labeled in accordance with UL 924 and shall be installed in accordance with the manufacturer's instructions and Section 1203. Exit signs shall be illuminated at all times.

(IFC 1013.5 2021)

The following violation was observed at the time of inspection:

The exit sign in the dining room is not illuminated.

17 Reliability

Required exit accesses, exits and exit discharges shall be continuously maintained free from obstructions or impediments to full instant use in the case of fire or other emergency when the building area served by the means of egress is occupied. An exit or exit passageway shall not be used for any purpose that interferes with a means of egress.

(IFC 1032.2 2021)

The following violation was observed at the time of inspection:

The exit pathway outside of memory care is completely covered by large amounts of leaves.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Prestige Senior Living Auburn Meadows	Provider Number	2239
Address	945 22ND ST NE,	Approval Status	Disapproved
City, State, Zip	Auburn, WA 98002	Facility Type	Residential Care

On 12/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

18 Maintenance

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required.

(IFC 1203.4 2021)

The following violation was observed at the time of inspection:

The facility was unable to provide documentation for the required weekly visual inspections of the generator as required by NFPA 110 for the last 12 months.

The facility was unable to provide documentation for the monthly 30 min load test of the generator as required by NFPA 110 for January, March, June, and November.

19 Fire Drills

In all Group I, Group E, and Group R2 Occupancies licensed by the state, at least twelve planned and unannounced fire drills shall be held every year. Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. A detailed written record of all fire drills shall be maintained and available for inspection at all times. When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms. Fire drills shall include the transmission of a fire alarm signal and simulation of emergency conditions. The fire alarm monitoring company shall be notified prior to the activation of the fire alarm system for drill purposes and again at the conclusion of the transmission and restoration of the fire alarm system to normal mode.

(WAC 212-12-044)

The following violation was observed at the time of inspection:

The facility was not able to provide documentation for the completion of twelve planned and unannounced fire drills in the previous 12 months.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Prestige Senior Living Auburn Meadows	Provider Number	2239
Address	945 22ND ST NE,	Approval Status	Disapproved
City, State, Zip	Auburn, WA 98002	Facility Type	Residential Care

On 12/24/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 01/23/2025


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

JAMES HEUPEL Maintenance Director
Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796


Signature