



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Cottage	Provider Number	2246
Address	3210 RICKEY RD NE,	Approval Status	Approved
City, State, Zip	Bremerton, WA 98310	Facility Type	Residential Care

On 01/22/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 114896

Here's a complaint of broken water pipes

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

COMPLAINT # 114896

On January 22, 2024 a complaint investigation was conducted at The Cottage at Bremerton located at 3210 Rickey Road N.E., Bremerton, WA 98310.

An interview was conducted with staff in regards to the sprinkler system being down due to a leak in the system. Fire watch was implemented while system was down, system has been fixed. All systems are normal.

There were no signs of a fire, the sprinkler system was activated due to a burst pipe, there was no evacuation, there were no injuries and fire department did respond.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

NOT AVAILABLE
Signature

Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

R. Murcia
Signature