



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Cottage	Provider Number	2246
Address	3210 RICKEY RD NE,	Approval Status	Approved
City, State, Zip	Bremerton, WA 98310	Facility Type	Residential Care

On 04/30/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Not Available
Signature

Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

[Signature]
Signature

This document was prepared by Residential Care Services for the Locator website.

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Cottage	Provider Number	2246
Address	3210 RICKEY RD NE,	Approval Status	Disapproved
City, State, Zip	Bremerton, WA 98310	Facility Type	Residential Care

On 01/08/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Record Keeping

Records shall be maintained of required emergency evacuation drills and include the following information:

1. Identity of the person conducting the drill.
2. Date and time of the drill.
3. Notification method used.
4. Employees on duty and participating.
5. Number of occupants evacuated.
6. Special conditions simulated.
7. Problems encountered.
8. Weather conditions when occupants were evacuated.
9. Time required to accomplish complete evacuation.

(IFC 0405.5 2018)

Findings during the inspection were:

Facility failed to provide signature pages for each fire drill conducted to verify participation.

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2009, 2012, 2015, 2018)

Findings during the inspection were:

Facility failed to provide documentation showing 3-year dry system full flow trip test.

Facility failed to maintain sprinkler system, system in yellow status and shall be in normal status.

3 Maintenance

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required.

(IFC 1203.4 2018)

Findings during the inspection were:

Facility failed to provide annual inspection report for generator.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Cottage	Provider Number	2246
Address	3210 RICKEY RD NE,	Approval Status	Disapproved
City, State, Zip	Bremerton, WA 98310	Facility Type	Residential Care

On 01/08/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

4 Securing Compressed Gas Containers, Cylinders and Tanks

Compressed gas containers, cylinders and tanks shall be secured to prevent falling caused by contact, vibration or seismic activity. Securing of compressed gas containers, cylinders and tanks shall be by one of the following methods:

1. Securing containers, cylinders and tanks to a fixed object with one or more restraints.
2. Securing containers, cylinders and tanks on a cart or other mobile device designed for the movement of compressed gas containers, cylinders or tanks.
3. Nesting of compressed gas containers, cylinders and tanks at container filling or servicing facilities or in sellers' warehouses not open to the public. Nesting shall be allowed provided that the nested containers, cylinders or tanks, if dislodged, do not obstruct the required means of egress.
4. Securing of compressed gas containers, cylinders and tanks to or within a rack, framework, cabinet or similar assembly designed for such use.

Exception: Compressed gas containers, cylinders and tanks in the process of examination, filling, transport or servicing.

(IFC 5303.5.3 2018)

Findings during the inspection were:

Facility failed to maintain oxygen tanks in oxygen rooms, tanks found unsecured.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Cottage	Provider Number	2246
Address	3210 RICKEY RD NE,	Approval Status	Disapproved
City, State, Zip	Bremerton, WA 98310	Facility Type	Residential Care

On 01/08/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 02/09/2024

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

NOT AVAILABLE
Signature

Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

[Signature]
Signature

This document was prepared by Residential Care Services for the Locator website.