




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Cottage	Provider Number	2246
Address	3210 RICKEY RD NE,	Approval Status	Approved
City, State, Zip	Bremerton, WA 98310	Facility Type	Residential Care

On 03/10/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

 Plant Operators Director
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

Raul Murcia Digitally signed by Raul Murcia
Date: 2025.03.13 14:41:14 -07'00'

Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Cottage	Provider Number	2246
Address	3210 RICKEY RD NE,	Approval Status	Disapproved
City, State, Zip	Bremerton, WA 98310	Facility Type	Residential Care

On 01/21/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Findings during the inspection were:

Two sprinkler heads in kitchen are loaded with debris. /

2 Emergency Lighting Equipment Inspection and Testing

Emergency lighting shall be maintained in accordance with Section 1008 and shall be inspected and tested in accordance with Sections 1031.10.1 and 1031.10.2.

(IFC 1032.10 2021)

Findings during the inspection were:

Exit sign by room 123 did not illuminate when tested. /



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Cottage	Provider Number	2246
Address	3210 RICKEY RD NE,	Approval Status	Disapproved
City, State, Zip	Bremerton, WA 98310	Facility Type	Residential Care

On 01/21/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

3 NFPA 80 Fire Door Inspection and Testing

5.2.1 Inspection and Testing. Upon completion of the installation, door, shutters, and window assemblies shall be inspected and tested in accordance with 5.2.4.
5.2.4 Periodic Inspection and Testing.
5.2.4.1 Periodic inspections and testing shall be performed not less than annually.

5.2.2.4 A record of all inspections and testing shall be provided that includes, but is not limited to, the following information:

1. Date of inspection
2. Name of facility
3. Address of facility
4. Name of person(s) performing inspections and testing
5. Company name and address of inspecting company
6. Signature of inspector of record
7. Individual record of each inspected and tested fire door assembly
8. Opening identifier and location of each inspected and tested fire door assembly
9. Type and description of each inspected and tested fire door assembly
10. Verification of visual inspection and functional operation
11. Listing of deficiencies in accordance with 5.2.3, Section 5.3, and Section 5.4

And the following shall be checked:

1. Labels are clearly visible and legible
2. No open holes or breaks exist in surfaces of wither the door or frame
3. Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.
4. The door, frame, hinges, hardware, and non combustible threshold are secured, aligned and in working order with no visible, signs of damage
5. No parts are missing or broken
6. Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7
7. The self-closing device is operational; that is, the active door completely closes when operated from the full open position
8. If a coordinator is installed, the inactive lead close before the active lead

Findings during the inspection were:

The following fire doors failed to latch;

- Double doors by kitchen.
- Double doors by room 112. ✓

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	The Cottage	Provider Number	2246
Address	3210 RICKEY RD NE,	Approval Status	Disapproved
City, State, Zip	Bremerton, WA 98310	Facility Type	Residential Care

On 01/21/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement


Statement of Violation

9. Latching hardware operates and secures the door when it is in the closed position
10. Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame
11. No field modification to the door assembly have been performed that void the label.
12. Meeting edge protection, gasketing and edge seals where required, are inspected to verify their presence and integrity
13. Signage affixed to a door meets the requirements listed in 4.1.4

Next inspection scheduled on or after: 02/22/2025


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature


Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067


Signature