




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Monroe	Provider Number	2284
Address	15465 179th AVE ,	Approval Status	Approved
City, State, Zip	Monroe, WA 98272	Facility Type	Residential Care

On 09/26/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature


Tena Bizanski Executive Director
Print Name and Title

Deputy State Fire Marshal Arthur Jesse Ward
2803 156TH AVE SE
Bellevue WA 98007
(425) 401-7735

Jesse Ward

Digitally signed by Jesse Ward
Date: 2024.09.26 07:49:44
-07'00'

Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Monroe	Provider Number	2284
Address	15465 179th AVE ,	Approval Status	Disapproved
City, State, Zip	Monroe, WA 98272	Facility Type	Residential Care

On 08/05/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
1 Abatement of Electrical Hazards	
Abatement of unsafe conditions and electrical hazards. Conditions that constitute an electrical shock or fire hazard shall be abated.. (IFC 603.2 2021)	There is an electrical outlet in room 306 missing a faceplate.
2 Smoke Barriers	
The fire-resistance rating and smoke-resistant characteristics of smoke barriers shall be maintained. (IFC 701.3 2021)	There are missing ceiling tiles throughout the facility. An assessment will need to be done and all missing tiles replaced.
3 Door Operation	
Swinging fire doors shall close from the full-open position and latch automatically. (IFC 705.2.4 2021)	The following fire doors did not operate. - Hallway door by 236 - Dining room fire door - Fire door by 307
4 Duct and Air Transfer Openings - Maintaining Protection	
Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced. (IFC 706.1 2018)	Facility is unable to provide documentation for the 4 year fire and smoke damper inspection. NFPA 80(2016) 19.5.1.1 Each damper shall be tested and inspected 1 year after acceptance testing. 19.5.1.2 The test and inspection frequency shall then be every 4 years, except in buildings containing a hospital, where the frequency shall be every 6 years.
5 Testing and Maintenance	
Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	- Facility is unable to provide documentation for the annual backflow forward flow test in accordance with NFPA 25. NFPA 25 (2017) - 13.7.2.1 - There is an escutcheon hanging off the sprinkler head in the kitchen dry goods storage.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Brookdale Monroe
Address 15465 179th AVE ,
City, State, Zip Monroe, WA 98272

Provider Number 2284
Approval Status Disapproved
Facility Type Residential Care

On 08/05/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
6 Extinguishing System Service	
Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion. (IFC 904.13.5.2 2021)	✓ Facility is unable to provide documentation for the semi-annual kitchen suppression system servicing.
7 Inspection, Testing and Maintenance	
The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	✓ - Facility is unable to provide documentation for the monthly single or multi station smoke alarm testing. - There is a smoke detector in room 217 hanging from the ceiling. ✓ - The fire alarm has a DACT trouble on it that needs to be repaired.
8 Carbon Monoxide Detection - General	
Carbon monoxide detection shall be installed in new buildings in accordance with Sections 915.1.1 through 915.6. Carbon monoxide detection shall be installed in existing buildings in accordance with Chapter 11 of the International Fire Code. (IFC 0915.1 2021 WAC 51-54A)	✓ Facility is unable to provide documentation for the monthly carbon monoxide detector testing. NFPA 720 8.7.1 Single - and multiple-station carbon monoxide alarms and all connected appliances shall be inspected and tested in accordance with the manufacturer's published instructions at least monthly.
9 Means of Egress Illumination	
Illumination shall be provided in the means of egress in accordance with Section 1008.2. Under emergency power, means of egress illumination shall comply with Section 1008.3. (IFC 1008.1 2021)	The exit stairway illumination throughout the building is not working. This needs to be fixed.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Monroe	Provider Number	2284
Address	15465 179th AVE ,	Approval Status	Disapproved
City, State, Zip	Monroe, WA 98272	Facility Type	Residential Care

On 08/05/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 09/04/2024

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Arthur Jesse Ward
2803 156TH AVE SE
Bellevue WA 98007
(425) 401-7735

Jesse Ward

Digitally signed by Jesse Ward
Date: 2024.08.06 15:01:38 -07'00'

Signature