




Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900


Business Name	Creekside Continuing Care Community	Provider Number	2316
Address	400 GILKEY RD ,	Approval Status	Approved
City, State, Zip	Burlington, WA	Facility Type	Residential Care

On 03/30/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature


Print Name and Title Marcus Oliver
Plant operations

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Creekside Continuing Care Community
Address 400 GILKEY RD ,
City, State, Zip Burlington, WA
Provider Number 2316
Approval Status Disapproved
Facility Type Residential Care

On 02/26/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.

(IFC 904.13.5.2 2021)

As per documents provided the kitchen suppression system testing conducted on 10/13/2025 had deficiencies noted that have not been corrected.

2 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

Facility is unable to provide documentation for the monthly single station smoke alarm testing.

Next inspection scheduled on or after: 03/28/2026


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Marcus Oliver Plant Operations Director
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037


Signature