



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

**Business Name**

13700 NE Salmon Creek AVE ,

**City, State, Zip**

Vancouver, WA 98686

**Provider Number** 2321

**Approval Status** Disapproved

**Facility Type** Residential Care

On 04/08/2024 the Office of the State Fire Marshal conducted a re-inspection at your facility. Listed below are violations that have not been corrected.

Code Requirement

Statement of Violation

**1 Testing and Maintenance**

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2009, 2012, 2015, 2018)

**Next inspection scheduled on or after:** 05/08/2024

Facility failed to provide forward flow flowing system demand  
Facility failed to provide 5 year hydrostatic testing

**Right of appeal.** Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

\_\_\_\_\_  
Signature

Deputy State Fire Marshal Nicholas Wolden  
1823 BAKER WAY  
Kelso WA 98626  
(360) 852-0966

\_\_\_\_\_  
Signature

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                             |                        |                  |
|-------------------------|-----------------------------|------------------------|------------------|
| <b>Business Name</b>    | Bonaventure of Salmon Creek | <b>Provider Number</b> | 2321             |
| <b>Address</b>          | 13700 NE Salmon Creek AVE , | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Vancouver, WA 68686         | <b>Facility Type</b>   | Residential Care |

On 02/28/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

**1 Testing and Maintenance**

|                                                                                                                            |                                                                                                                        |
|----------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------|
| Sprinkler systems shall be tested and maintained in accordance with Section 901.<br><br>(IFC 903.5 2009, 2012, 2015, 2018) | The facility failed to provide the following reports<br><br>5 year internal<br>5 year FDC hydro<br>Annual forward flow |
|----------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------|

**2 Extinguishing System Service**

|                                                                                                                                                                                                                                                                                                               |  |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.<br><br>(IFC 904.12.5.2 2018) |  |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|

**3 Activation Test**

|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |  |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| Emergency lighting equipment shall be tested monthly for a duration of not less than 30 seconds. The test shall be performed manually or by an automated self-testing and self-diagnostic routine. Where testing is performed by self-testing and self-diagnostics, a visual inspection of the emergency lighting equipment shall be conducted monthly to identify any equipment displaying a trouble indicator or that has become damaged or otherwise impaired.<br><br>(IFC 1031.10.1 2018) |  |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|

**4 Power Test**

|                                                                                                                                                                             |                                                           |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
| Battery-powered emergency lighting equipment shall be tested annually by operating the equipment on battery power for not less than 90 minutes.<br><br>(IFC 1031.10.2 2018) | Facility failed to provide annual emergency light testing |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                             |                        |                  |
|-------------------------|-----------------------------|------------------------|------------------|
| <b>Business Name</b>    | Bonaventure of Salmon Creek | <b>Provider Number</b> | 2321             |
| <b>Address</b>          | 13700 NE Salmon Creek AVE , | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Vancouver, WA 68686         | <b>Facility Type</b>   | Residential Care |

On 02/28/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

**5 Maintenance**

|                                                                                                                                                                                                                                              |                                                                                                            |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|
| Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required.<br><br>(IFC 1203.4 2018) | Facility failed to provide the following reports<br><br>Annual generator inspection<br>Annual fuel testing |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|

**6 Fire Drills**

|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |  |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| In all Group I, Group E, and Group R2 Occupancies licensed by the state, at least twelve planned and unannounced fire drills shall be held every year. Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. A detailed written record of all fire drills shall be maintained and available for inspection at all times. When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms. Fire drills shall include the transmission of a fire alarm signal and simulation of emergency conditions. The fire alarm monitoring company shall be notified prior to the activation of the fire alarm system for drill purposes and again at the conclusion of the transmission and restoration of the fire alarm system to normal mode.<br><br>(WAC 212-12-044) |  |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                             |                        |                  |
|-------------------------|-----------------------------|------------------------|------------------|
| <b>Business Name</b>    | Bonaventure of Salmon Creek | <b>Provider Number</b> | 2321             |
| <b>Address</b>          | 13700 NE Salmon Creek AVE , | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Vancouver, WA 68686         | <b>Facility Type</b>   | Residential Care |

On 02/28/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

**Next inspection scheduled on or after: 03/29/2024**

**Right of appeal.** Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

\_\_\_\_\_  
*Signature*

\_\_\_\_\_  
*Print Name and Title*

Deputy State Fire Marshal Nicholas Wolden  
1823 BAKER WAY  
Kelso WA 98626  
(360) 852-0966

\_\_\_\_\_  
*Signature*

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                             |                        |                  |
|-------------------------|-----------------------------|------------------------|------------------|
| <b>Business Name</b>    | Bonaventure of Salmon Creek | <b>Provider Number</b> | 2321             |
| <b>Address</b>          | 13700 NE Salmon Creek AVE , | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Vancouver, WA 68686         | <b>Facility Type</b>   | Residential Care |

On 01/29/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

**1 Testing and Maintenance**

|                                                                                                                            |                                                                                                                                                                                           |
|----------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Sprinkler systems shall be tested and maintained in accordance with Section 901.<br><br>(IFC 903.5 2009, 2012, 2015, 2018) | The facility failed to provide the following reports<br><br>5 year internal<br>5 year FDC hydro<br>Annual dry system trip test<br>3 year dry system trip test<br>Annual forward flow test |
|----------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**2 Extinguishing System Service**

|                                                                                                                                                                                                                                                                                                               |                                                                      |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------|
| Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.<br><br>(IFC 904.12.5.2 2018) | Facility failed to provide semi annual hood system inspection report |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------|

**3 Activation Test**

|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |                                                                             |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------|
| Emergency lighting equipment shall be tested monthly for a duration of not less than 30 seconds. The test shall be performed manually or by an automated self-testing and self-diagnostic routine. Where testing is performed by self-testing and self-diagnostics, a visual inspection of the emergency lighting equipment shall be conducted monthly to identify any equipment displaying a trouble indicator or that has become damaged or otherwise impaired.<br><br>(IFC 1031.10.1 2018) | Facility failed to provide documentation of monthly emergency light testing |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------|

**4 Power Test**

|                                                                                                                                                                             |                                                           |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|
| Battery-powered emergency lighting equipment shall be tested annually by operating the equipment on battery power for not less than 90 minutes.<br><br>(IFC 1031.10.2 2018) | Facility failed to provide annual emergency light testing |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------|

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                             |                        |                  |
|-------------------------|-----------------------------|------------------------|------------------|
| <b>Business Name</b>    | Bonaventure of Salmon Creek | <b>Provider Number</b> | 2321             |
| <b>Address</b>          | 13700 NE Salmon Creek AVE , | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Vancouver, WA 68686         | <b>Facility Type</b>   | Residential Care |

On 01/29/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

**5 Maintenance**

|                                                                                                                                                                                                                                              |                                                                                                                                             |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------|
| Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required.<br><br>(IFC 1203.4 2018) | Facility failed to provide the following reports<br><br>Annual generator inspection<br>Monthly generator run testing<br>Annual fuel testing |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------|

**6 Fire Drills**

|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                                                                   |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|
| In all Group I, Group E, and Group R2 Occupancies licensed by the state, at least twelve planned and unannounced fire drills shall be held every year. Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. A detailed written record of all fire drills shall be maintained and available for inspection at all times. When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms. Fire drills shall include the transmission of a fire alarm signal and simulation of emergency conditions. The fire alarm monitoring company shall be notified prior to the activation of the fire alarm system for drill purposes and again at the conclusion of the transmission and restoration of the fire alarm system to normal mode.<br><br>(WAC 212-12-044) | Facility failed to conduct fire drills once per shift per quarter |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------|

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

|                         |                             |                        |                  |
|-------------------------|-----------------------------|------------------------|------------------|
| <b>Business Name</b>    | Bonaventure of Salmon Creek | <b>Provider Number</b> | 2321             |
| <b>Address</b>          | 13700 NE Salmon Creek AVE , | <b>Approval Status</b> | Disapproved      |
| <b>City, State, Zip</b> | Vancouver, WA 68686         | <b>Facility Type</b>   | Residential Care |

On 01/29/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

**Next inspection scheduled on or after: 02/28/2024**

**Right of appeal.** Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

\_\_\_\_\_  
*Signature*

\_\_\_\_\_  
*Print Name and Title*

Deputy State Fire Marshal Nicholas Wolden  
1823 BAKER WAY  
Kelso WA 98626  
(360) 852-0966

\_\_\_\_\_  
*Signature*

This document was prepared by Residential Care Services for the Locator website.