



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Bonaventure of Salmon Creek	Provider Number	2321
Address	13700 NE Salmon Creek AVE ,	Approval Status	Approved
City, State, Zip	Vancouver, WA	Facility Type	Residential Care

On 01/29/2026 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 210065 Here's a complaint of Fire Alarm Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	Fire alarm heat detector in kitchen was setting off the fire alarm system due to rapid rise in temperature. Heat detector found within 36 inch of diffuser
---	--

2 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained. (IFC 907.8 2021)	Heat detector in kitchen found to close to heat diffuser NFPA 72 17.7.4.1
--	--

Next inspection scheduled on or after: 02/28/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 852-0966

Signature