



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Meridian at Stone Creek (The)	Provider Number	2365
Address	1111 S 376th ST ,	Approval Status	Approved
City, State, Zip	Milton, WA 98354	Facility Type	Residential Care

On 06/04/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 178945

Here's a complaint of Smoking / Fire

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? Ashtray outside / unknown how it started
2. If the sprinklers were activated? No
3. If there was an evacuation / how many were evacuated? 0
4. If there were injuries / how many? 0
5. Did the fire department respond? Yes

On June 04, 2025 DSFM Christian entered The Meridian at Stone Creek located at 1111 S 376 St., Milton Wa 98354 to investigate complaint ref # 178945. I interviewed the Executive Director and Maintenance Director.

On May 12, 2025 a fire was discovered burning outside of the building in the smoking area. It was approximately 3:15 am and the front doors were locked. The E.D stated that no residents are out after the doors are locked and it could possibly have been a staff member who had been smoking, however they could not confirm.

A staff member was looking out the window and noticed smoke out front and saw the fire. The staff member called 911, and the fire department showed up and put out the fire. When asked if the staffed had grabbed a fire extinguisher the E.D and Maintenance Director said no. The person who saw the fire thought the fire was too big. The fire burnt the entire plastic ash tray and a nearby chair. Since the incident the facility has replaced the ashtray with the required metal canister, and has since provided training to staff. It was recommended they add a fire blanket or extinguisher to the area, however it is not required.

No IFC violations observed

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Meridian at Stone Creek (The)	Provider Number	2365
Address	1111 S 376th ST ,	Approval Status	Approved
City, State, Zip	Milton, WA 98354	Facility Type	Residential Care

On 06/04/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after:


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Shylah Halbam-voel
Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796


Signature

This document was prepared by Residential Care Services for the Locator website.