



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

This document was prepared by Residential Care Services for the Locator website.

Business Name	Meridian at Stone Creek (The)	Provider Number	2365
Address	1111 S 376th ST ,	Approval Status	Disapproved
City, State, Zip	Milton, WA 98354	Facility Type	Residential Care

On 06/04/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Administration

	On 06/04/2025 an unannounced Fire and Life Safety Code re-inspection was conducted at The Meridian at Stone Creek by a representative of the Washington State Patrol, State Fire Marshal's Office to determine compliance with all applicable codes. The following deficiencies were cited as a result of this re-inspection:
--	---

2 Duct and Air Transfer Openings - Maintaining Protection

Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced. (IFC 706.1 2018)	The following violation was observed at the time of re-inspection: The facilities damper report shows that the following dampers failed: 1. 3rd floor storage 2. 3rd floor laundry The facility failed to label all damper access panels with the words "Fire Damper". Letters should be not less than 1 in. (25 mm) in height.
--	--

3 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	The following violation was observed at the time of re-inspection: The facility was unable to provide documentation for: 1. Annual standpipe confidence report 2. 3 year dry system full flow trip test
---	---



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

This document was prepared by Residential Care Services for the Locator website.

Business Name	Meridian at Stone Creek (The)	Provider Number	2365
Address	1111 S 376th ST ,	Approval Status	Disapproved
City, State, Zip	Milton, WA 98354	Facility Type	Residential Care

On 06/04/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

4 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion. (IFC 904.13.5.2 2021)	Corrected
---	-----------

5 Maintenance

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	Corrected
--	-----------

Next inspection scheduled on or after: 07/04/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Shylah Hallam-Coe
Print Name and Title

Deputy State Fire Marshal Cozetta Christian
2502 112TH E
Tacoma WA 984455104
(360) 584-5796

Signature



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Meridian at Stone Creek (The)
1111 S 376th ST ,
City, State, Zip Milton, WA 98354

Provider Number 2365
Approval Status Disapproved
Facility Type Residential Care

On 02/12/2025 the Office of the State Fire Marshal conducted a re-inspection at your facility. Listed below are violations that have not been corrected.

Code Requirement	Statement of Violation
------------------	------------------------

1 Duct and Air Transfer Openings - Maintaining Protection

Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced.

(IFC 706.1 2018)

Findings during the re-inspection were:

- 1) Unable to provide documentation showing that all automatic and fusible link fire/smoke dampers in the facility have received inspection and testing in the past four years, per NFPA 80, 19.5.3. If fusible link dampers have not received inspection/testing in the past four years, service scheduling shall be required.
- 2) Facility shall label all damper access panels with the words "Fire Damper" in letters not less than 1 in. (25 mm) in height.

2 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Findings during the re-inspection were:

- Unable to provide fire sprinkler system documentation for the following:
- Last annual standpipe confidence report
 - Last 3-year full flow trip test report
 - Last 5-year inspection/test report(s)
 - Last 5-year FDC hydro test report - unknown if conducted, scheduling required

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name

1111 S 376th ST ,

City, State, Zip

Milton, WA 98354

Provider Number 2365

Approval Status Disapproved

Facility Type Residential Care

On 02/12/2025 the Office of the State Fire Marshal conducted a re-inspection at your facility. Listed below are violations that have not been corrected.

Code Requirement	Statement of Violation
------------------	------------------------

3Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.

(IFC 904.13.5.2 2021)

Findings during the re-inspection were:

The 10/9/24 kitchen hood suppression system report indicated that the cooking appliances were out of line with the suppression system nozzles, affecting system performance and coverage in the event of an activation. Staff stated that a new range was purchased after the fire in September that was larger than the original one.

Facility shall work with DOH Construction Review Services to ensure that system design provides the correct coverage/protection.

No corrective Cintas report approving appliance location, clearing yellow-tag.

4Maintenance

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required.

(IFC 1203.4 2021)

Findings during the re-inspection were:

1) Unable to provide documentation showing that annual servicing of the emergency backup generator has been performed in the past 12 months.

2) Unable to provide documentation showing that diesel fuel is in compliance with manufacturer's recommendations - no fuel sample report available.

3) Unable to provide documentation showing the emergency generator has received monthly load tests for the past 12 months.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Provider Number 2365
1111 S 376th ST ,	Approval Status Disapproved
City, State, Zip Milton, WA 98354	Facility Type Residential Care

On 02/12/2025 the Office of the State Fire Marshal conducted a re-inspection at your facility. Listed below are violations that have not been corrected.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 03/17/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Deputy State Fire Marshal Lysandra Davis
2502 112 ST
Tacoma WA 984455104
(360) 890-1622

Signature

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Meridian at Stone Creek (The)
1111 S 376th ST ,
City, State, Zip Milton, WA 98354

Provider Number 2365
Approval Status Disapproved
Facility Type Residential Care

On 12/10/2024 the Office of the State Fire Marshal conducted a re-inspection at your facility. Listed below are violations that have not been corrected.

Code Requirement	Statement of Violation
------------------	------------------------

1 Owner's Responsibility

The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space.

(IFC 701.6 2021)

Findings during the re-inspection were:

Unable to provide last annual inspection of all fire-resistant-rated construction assemblies in the building, or record of repairs.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Meridian at Stone Creek (The)
1111 S 376th ST ,
City, State, Zip Milton, WA 98354

Provider Number 2365
Approval Status Disapproved
Facility Type Residential Care

On 12/10/2024 the Office of the State Fire Marshal conducted a re-inspection at your facility. Listed below are violations that have not been corrected.

Code Requirement	Statement of Violation
2 Inspection and Maintenance	

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified.

(IFC 705.2 2021)

Findings during the re-inspection were:

Unable to provide record showing that all fire doors have been annually inspected, tested and repaired in the past 12 months--facility only had partial records.

3 Duct and Air Transfer Openings - Maintaining Protection

Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced.

(IFC 706.1 2018)

Findings during the re-inspection were:

1) Unable to provide documentation showing that all automatic and fusible link fire/smoke dampers in the facility have received inspection and testing in the past four years, per NFPA 80, 19.5.3. If fusible link dampers have not received inspection/testing in the past four years, service scheduling shall be required.

2) Facility shall label all damper access panels with the words "Fire Damper" in letters not less than 1 in. (25 mm) in height.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Meridian at Stone Creek (The)
1111 S 376th ST ,
City, State, Zip Milton, WA 98354

Provider Number 2365
Approval Status Disapproved
Facility Type Residential Care

On 12/10/2024 the Office of the State Fire Marshal conducted a re-inspection at your facility. Listed below are violations that have not been corrected.

Code Requirement	Statement of Violation
4 Testing and Maintenance	
Sprinkler systems shall be tested and maintained in accordance with Section 901. (IFC 903.5 2021)	Findings during the re-inspection were: Unable to provide fire sprinkler system documentation for the following: - Last annual forward flow test report - not conducted, scheduling required - Last annual standpipe confidence report - Last 3-year full flow trip test report - Last 5-year inspection/test report(s) - Last 5-year FDC hydro test report - unknown if conducted, scheduling required
5 Extinguishing System Service	
Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion. (IFC 904.13.5.2 2021)	Findings during the re-inspection were: The 10/9/24 kitchen hood suppression system report indicated that the cooking appliances were out of line with the suppression system nozzles, affecting system performance and coverage in the event of an activation. Staff stated that a new range was purchased after the fire in September that was larger than the original one. Facility shall work with DOH Construction Review Services to ensure that system design provides the correct coverage/protection.
6 Maintenance	
Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	Findings during the re-inspection were: 1) Unable to provide documentation showing that annual servicing of the emergency backup generator has been performed in the past 12 months. 2) Unable to provide documentation showing that diesel fuel is in compliance with manufacturer's recommendations - no fuel sample report available. 3) Unable to provide documentation showing the emergency generator has received monthly load tests for the past 12 months.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Meridian at Stone Creek (The)
1111 S 376th ST ,
City, State, Zip Milton, WA 98354

Provider Number 2365
Approval Status Disapproved
Facility Type Residential Care

On 12/10/2024 the Office of the State Fire Marshal conducted a re-inspection at your facility. Listed below are violations that have not been corrected.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 01/09/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Deputy State Fire Marshal Lysandra Davis
2502 112 ST
Tacoma WA 984455104
(360) 890-1622

Signature

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name The Meridian at Stone Creek
1111 S 376th ST ,
City, State, Zip Milton, WA 98354

Provider Number 2365
Approval Status Disapproved
Facility Type Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted a re-inspection at your facility. Listed below are violations that have not been corrected.

Code Requirement	Statement of Violation
------------------	------------------------

1 Circuit identification and Accessibility

10.6.5.2 Circuit Identification and Accessibility.
10.6.5.2.1 The location of the branch circuit disconnecting means shall be permanently identified at the control unit.
10.6.5.2.2 System circuit disconnecting means shall be permanently identified as to its purpose in accordance with the following:
(1) "FIRE ALARM" for fire alarm systems
(2) "EMERGENCY COMMUNICATIONS" for emergency communications systems
(3) "FIRE ALARM/ECS" for combination fire alarm and emergency communications systems
10.6.5.2.3 For fire alarm and/or signaling systems, the circuit disconnecting means shall have a red marking.
10.6.5.2.4 The red marking shall not damage the overcurrent protective devices or obscure the manufacturer's markings.
10.6.5.2.5 The circuit disconnecting means shall be accessible only to authorized personnel.
10.6.5.3 Mechanical Protection. The branch circuit(s) and connections shall be protected against physical damage.
10.6.5.4 Circuit Breaker Lock. Where a circuit breaker is the disconnecting means, a listed breaker locking device shall be installed.
10.6.5.5 Overcurrent Protection. An overcurrent protective device of suitable current-carrying capacity that is capable of interrupting the maximum short-circuit current to which it can be subject shall be provided in each ungrounded conductor.

Findings during the re-inspection were:

Fire alarm circuit breaker in the main electrical room--Panels --was found missing the required lock device--locking breaker in the "ON" position.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name The Meridian at Stone Creek
1111 S 376th ST ,
City, State, Zip Milton, WA 98354

Provider Number 2365
Approval Status Disapproved
Facility Type Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted a re-inspection at your facility. Listed below are violations that have not been corrected.

Code Requirement	Statement of Violation
------------------	------------------------

(NFPA 72 10.6.5.2)

2 Owner's Responsibility

The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space.

(IFC 701.6 2021)

Findings during the re-inspection were:

Unable to provide last annual inspection of all fire-resistant-rated construction assemblies in the building, or record of repairs.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name The Meridian at Stone Creek
1111 S 376th ST ,
City, State, Zip Milton, WA 98354

Provider Number 2365
Approval Status Disapproved
Facility Type Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted a re-inspection at your facility. Listed below are violations that have not been corrected.

Code Requirement	Statement of Violation
3 Inspection and Maintenance	
Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified. (IFC 705.2 2021)	Findings during the re-inspection were: Unable to provide record showing that fire doors have been annually inspected, tested and repaired in the past 12 months.
4 Door Operation	
Swinging fire doors shall close from the full-open position and latch automatically. (IFC 705.2.4 2021)	Findings during the re-inspection were: Both 'in' and 'out' fire-rated doors between kitchen and dining room have had the lever/latch hardware removed and replaced with keyed deadbolt lock; doors no longer latch.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name The Meridian at Stone Creek
1111 S 376th ST ,
City, State, Zip Milton, WA 98354

Provider Number 2365
Approval Status Disapproved
Facility Type Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted a re-inspection at your facility. Listed below are violations that have not been corrected.

Code Requirement	Statement of Violation
------------------	------------------------

5 Duct and Air Transfer Openings - Maintaining Protection

Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced.

(IFC 706.1 2018)

Findings during the re-inspection were:

- 1) Unable to provide documentation showing that all automatic and fusible link fire/smoke dampers in the facility have received inspection and testing in the past four years, per NFPA 80, 19.5.3. If fusible link dampers have not received inspection/testing in the past four years, service scheduling shall be required.
- 2) Facility shall label all damper access panels with the words "Fire Damper" in letters not less than 1 in. (25 mm) in height.

6 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Findings during the re-inspection were:

- Unable to provide fire sprinkler system documentation for the following:
- Last annual forward flow test report - not conducted, scheduling required
 - Last annual standpipe confidence report
 - Last 3-year full flow trip test report - conducted May 2023
 - Last 5-year inspection/test report(s) - conducted Feb. 2020
 - Last 5-year FDC hydro test report - unknown if conducted, scheduling required

7 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.

(IFC 904.13.5.2 2021)

Findings during the re-inspection were:

Found kitchen hood suppression system past due for semi-annual servicing - last performed in May 2023.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name The Meridian at Stone Creek
1111 S 376th ST.
City, State, Zip Milton, WA 98354

Provider Number 2365
Approval Status Disapproved
Facility Type Residential Care

On 09/25/2024 the Office of the State Fire Marshal conducted a re-inspection at your facility. Listed below are violations that have not been corrected.

Code Requirement	Statement of Violation
8 Maintenance Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required. (IFC 1203.4 2021)	Findings during the re-inspection were: 1) Unable to provide documentation showing that annual servicing of the emergency backup generator has been performed in the past 12 months. 2) Unable to provide documentation showing that diesel fuel is in compliance with manufacturer's recommendations - no fuel sample report available. 3) Unable to provide documentation showing the emergency generator has received monthly load tests for the past 12 months.

Next inspection scheduled on or after: 10/21/2024

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Deputy State Fire Marshal Lysandra Davis
2502 112 ST
Tacoma WA 984455104
(360) 890-1622

Signature

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

This document was prepared by Residential Care Services for the Locator website.

Business Name Meridian at Stone Creek (The)

Provider Number 2365

Address 1111 S 376th ST ,

Approval Status Disapproved

City, State, Zip Milton, WA 98354

Facility Type Residential Care

On 07/22/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Abatement of Electrical Hazards

Abatement of unsafe conditions and electrical hazards. Conditions that constitute an electrical shock or fire hazard shall be abated..

(IFC 603.2 2021)

Findings during the inspection were:

Light switch in kitchen pantry is missing required cover plate.

2 Working Space and Clearance

Working space and clearances. Working space around electrical equipment shall be provided in accordance with Section 110.26 of NFPA 70 for electrical equipment rated 1,000 volts or less, and Section 110.32 of NFPA 70 for electrical equipment rated over 1,000 volts. The minimum required working space shall be not less than 30 inches (762 mm) in width, 36 inches (914 mm) in depth and 78 inches (1981 mm) in height in front of electrical service equipment. Where the electrical service equipment is wider than 30 inches (762 mm), the minimum working space shall be not less than the width of the equipment. Storage of materials shall not be located within the designated working space.

(IFC 603.4, 2021)

Findings during the inspection were:

Facility failed to maintain required workspace clearance in front of electrical panels in:
- Mechanical room by W214
- Mechanical room by E116

3 Extension Cords

Extension cords. Extension cords shall not be a substitute for permanent wiring and shall be listed and labeled in accordance with UL 817. Extension cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances. Extension cords marked for indoor use shall not be used outdoors.

(IFC 603.6 2021)

Findings during the inspection were:

1) Extension cords found utilized as permanent wiring in the following locations:

- Activity room 1, powering vending machine
- Clinical support office (labeled storage room), powering devices by desk
- Service hall laundry room, powering refrigerator

2) Extension cord found extended and concealed above ceiling tiles, powering the refrigerator in service hall laundry room.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Meridian at Stone Creek (The)

Provider Number 2365

Address 1111 S 376th ST ,

Approval Status Disapproved

City, State, Zip Milton, WA 98354

Facility Type Residential Care

On 07/22/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

4 Cleaning

Hoods, grease-removal devices, fans, ducts and other appurtenances shall be cleaned at intervals as required by Sections 606.3.3.1 through 606.3.3.3.

(IFC 606.3.3 2021)

Findings during the inspection were:

Unable to provide reports showing that four (4) quarterly kitchen hood cleanings have been performed in the past 12 months, as required by NFPA 96.

5 Owner's Responsibility

The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the International Building Code. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space.

(IFC 701.6 2021)

Findings during the inspection were:

Unable to provide last annual inspection of all fire-resistant-rated construction assemblies in the building, or record of repairs.

6 Penetrations - Maintaining Protection

Materials and firestop systems used to protect membrane and through penetrations in fire-resistance-rated construction and construction installed to resist the passage of smoke shall be maintained. The materials and firestop systems shall be securely attached to or bonded to the construction being penetrated with no openings visible through or into the cavity of the construction. Where the system design number is known, the system shall be inspected to the listing criteria and manufacturer's installation instructions.

(IFC 703.1 2021)

Findings during the inspection were:

- 1) Unsealed penetrations observed in the following locations:
 - Exterior access boiler room - in rated ceiling
 - Exterior riser room (by main entrance) - in rated wall
- 2) Found unapproved silicone used to protect penetration inside the mechanical room, across from W303--around the overhead pipe entering the interior storage room.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Meridian at Stone Creek (The)
Address 1111 S 376th ST ,
City, State, Zip Milton, WA 98354

Provider Number 2365
Approval Status Disapproved
Facility Type Residential Care

On 07/22/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

7 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified.

(IFC 705.2 2021)

Findings during the inspection were:

Unable to provide record showing that fire doors have been annually inspected, tested and repaired in the past 12 months.

8 Door Operation

Swinging fire doors shall close from the full-open position and latch automatically.

(IFC 705.2.4 2021)

Findings during the inspection were:

The following fire doors failed to self-close and latch when tested:

- Storage room by E316; latch hardware inoperable
- Storage room by W134; disengaged/disabled self-closer
- MC corridor door by W132; transition strip prevents door from closing
- MC corridor door by W114; push bar locked in open position
- MC corridor door by W137; latch hardware inoperable
- Service hall laundry room; door propped open
- Both 'in' and 'out' doors between kitchen/dining room; latch hardware replaced with deadbolt locks

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

This document was prepared by Residential Care Services for the Locator website.

Business Name	Meridian at Stone Creek (The)	Provider Number	2365
Address	1111 S 376th ST ,	Approval Status	Disapproved
City, State, Zip	Milton, WA 98354	Facility Type	Residential Care

On 07/22/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

9 Duct and Air Transfer Openings - Maintaining Protection

Dampers protecting ducts and air transfer openings shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Other products or materials used to protect the openings for ducts and air transfer openings shall be securely attached to or bonded to the construction containing the duct or air transfer opening, without visible openings through or into the cavity of the construction. Any damaged products or materials protecting duct and air transfer openings shall be repaired, restored or replaced.

(IFC 706.1 2018)

Findings during the inspection were:

- 1) Unable to provide documentation showing that all automatic and fusible link fire/smoke dampers in the facility have received inspection and testing in the past four years, per NFPA 80, 19.5.3. If fusible link dampers have not received inspection/testing in the past four years, service scheduling shall be required.
- 2) Dampers by E316, E216, and E116 were coated in excessive dust build-up. Unable to verify that they have received inspection and testing in the past four years--no inspection labels visible.
- 3) Facility shall label all damper access panels with the words "Fire Damper" in letters not less than 1 in. (25 mm) in height.

10 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Findings during the inspection were:

- 1) Unable to provide fire sprinkler system documentation for the following:
 - Quarterly inspection reports - three performed in the last 12 months
 - Last annual confidence test report - conducted Jan. 2024
 - Last annual forward flow test report - not conducted, scheduling require
 - Last annual standpipe confidence report
 - Last 3-year full flow trip test report - conducted May 2023
 - Last 5-year inspection/test report(s) - conducted Feb. 2020
 - Last 5-year FDC hydro test report - unknown if conducted, scheduling required
- 2) Cover plate behind recessed sprinkler head shall be required in mechanical room by W214 - notable gap in sheetrock observed around sprinkler head.
- 3) Found ordinary-rated fire sprinkler heads in the walk-in cooler and freezer - replace heads with intermediate-temperature classification or higher required.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Meridian at Stone Creek (The)
Address 1111 S 376th ST ,
City, State, Zip Milton, WA 98354

Provider Number 2365
Approval Status Disapproved
Facility Type Residential Care

On 07/22/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

11 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.

(IFC 904.13.5.2 2021)

Findings during the inspection were:

Found kitchen hood suppression system past due for semi-annual servicing - last performed in May 2023.

12 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

Findings during the inspection were:

Unable to provide documentation showing that annual servicing of the fire alarm system has been performed in the past 12 months.

13 Maintenance

Carbon monoxide alarms and carbon monoxide detection systems shall be maintained in accordance with NFPA 72. Carbon monoxide alarms and carbon monoxide detectors that become inoperable or begin producing end-of-life signals shall be replaced.

(IFC 915.6 2021 WAC)

Findings during the inspection were:

Unable to provide documentation showing that monthly inspection of the facility's carbon monoxide alarms has been performed in the past 12 months.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Meridian at Stone Creek (The)	Provider Number	2365
Address	1111 S 376th ST ,	Approval Status	Disapproved
City, State, Zip	Milton, WA 98354	Facility Type	Residential Care

On 07/22/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

14 Graphics

Externally illuminated exit signs shall comply with Sections 1013.6.1 through 1013.6.3

Every exit sign and directional exit sign shall have plainly legible letters not less than 6 inches (152 mm) high with the principal strokes of the letters not less than 3/4 inch (19.1 mm) wide. The word "EXIT" shall have letters having a width not less than 2 inches (51 mm) wide, except the letter "I," and the minimum spacing between letters shall not be less than 3/8 inch (9.5 mm). Signs larger than the minimum established in this section shall have letter widths, strokes and spacing in proportion to their height.

The word "EXIT" shall be in high contrast with the background and shall be clearly discernible when the means of exit sign illumination is or is not energized. If a chevron directional indicator is provided as part of the exit sign, the construction shall be such that the direction of the chevron directional indicator cannot be readily changed.

(IFC 1013.6.1 2021)

Findings during the inspection were:

Exit sign by W209 has internal part blocking light bulb; preventing full illumination of exit sign lettering on front and back.

15 Activation Test

Emergency lighting equipment shall be tested monthly for a duration of not less than 30 seconds. The test shall be performed manually or by an automated self-testing and self-diagnostic routine. Where testing is performed by self-testing and self-diagnostics, a visual inspection of the emergency lighting equipment shall be conducted monthly to identify any equipment displaying a trouble indicator or that has become damaged or otherwise impaired.

(IFC 1032.10.1 2021)

Findings during the inspection were:

Unable to provide documentation showing that 30-second monthly battery testing of the facility's emergency lighting and exit signs has been performed in the last 12 months.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Meridian at Stone Creek (The)

Provider Number 2365

Address 1111 S 376th ST ,

Approval Status Disapproved

City, State, Zip Milton, WA 98354

Facility Type Residential Care

On 07/22/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

16 Power Test

Battery-powered emergency lighting equipment shall be tested annually by operating the equipment on battery power for not less than 90 minutes.

(IFC 1031.10.2 2021)

Findings during the inspection were:

- 1) Unable to provide documentation showing that 90-minute annual battery testing of the emergency lighting and exit signs has been performed in the past 12 months.
- 2) Facility will need to conduct a 90-minute annual test of all emergency lighting and exit signs in the building to be in compliance by the re-inspection date.

17 Reliability

Required exit accesses, exits and exit discharges shall be continuously maintained free from obstructions or impediments to full instant use in the case of fire or other emergency when the building area served by the means of egress is occupied. An exit or exit passageway shall not be used for any purpose that interferes with a means of egress.

(IFC 1032.2 2021)

Findings during the inspection were:

Exterior lever handle on west dining room exit doors is installed backwards--obstructing the interior right leaf from opening when the left leaf is latched. Facility has cinched a strap around the left leaf's interior push bar, which allows the right leaf to open, as it pushes the left leaf's lever handle out of the way.

18 Maintenance

Emergency and standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 such that the system is capable of supplying service within the time specified for the type and duration required.

(IFC 1203.4 2021)

Findings during the inspection were:

- 1) Unable to provide documentation showing that annual servicing of the emergency backup generator has been performed in the past 12 months.
- 2) Unable to provide documentation showing that diesel fuel is in compliance with manufacturer's recommendations - no fuel sample report available.
- 3) Unable to provide documentation showing the emergency generator has received monthly load tests for the past 12 months.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Meridian at Stone Creek (The)	Provider Number	2365
Address	1111 S 376th ST ,	Approval Status	Disapproved
City, State, Zip	Milton, WA 98354	Facility Type	Residential Care

On 07/22/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

19 Securing Compressed Gas Containers, Cylinders and Tanks

Compressed gas containers, cylinders and tanks shall be secured to prevent falling caused by contact, vibration or seismic activity. Securing of compressed gas containers, cylinders and tanks shall be by one of the following methods:

1. Securing containers, cylinders and tanks to a fixed object with one or more restraints.
2. Securing containers, cylinders and tanks on a cart or other mobile device designed for the movement of compressed gas containers, cylinders or tanks.
3. Nesting of compressed gas containers, cylinders and tanks at container filling or servicing facilities or in sellers' warehouses not open to the public. Nesting shall be allowed provided that the nested containers, cylinders or tanks, if dislodged, do not obstruct the required means of egress.
4. Securing of compressed gas containers, cylinders and tanks to or within a rack, framework, cabinet or similar assembly designed for such use.

Exception: Compressed gas containers, cylinders and tanks in the process of examination, filling, transport or servicing.

(IFC 5303.5.3 2021)

Findings during the inspection were:

Two unracked oxygen cylinder found in resident room W334--one on floor and one on table.

20 Inspection Frequency

Fire extinguishers shall be inspected when initially placed in service and thereafter at approximately 30-day intervals. Fire extinguishers shall be inspected, manually or by electronic monitoring, at more frequent intervals when circumstances require.

(NFPA Standard 10 Section 6.2.1)

Findings during the inspection were:

Portable fire extinguishers throughout the facility did not have the required 30-day inspections documented for April, May, or June of 2024.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Meridian at Stone Creek (The)	Provider Number	2365
Address	1111 S 376th ST ,	Approval Status	Disapproved
City, State, Zip	Milton, WA 98354	Facility Type	Residential Care

On 07/22/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

21 Circuit identification and Accessibility

10.6.5.2 Circuit Identification and Accessibility.
10.6.5.2.1 The location of the branch circuit disconnecting means shall be permanently identified at the control unit.
10.6.5.2.2 System circuit disconnecting means shall be permanently identified as to its purpose in accordance with the following:
(1) "FIRE ALARM" for fire alarm systems
(2) "EMERGENCY COMMUNICATIONS" for emergency communications systems
(3) "FIRE ALARM/ECS" for combination fire alarm and emergency communications systems
10.6.5.2.3 For fire alarm and/or signaling systems, the circuit disconnecting means shall have a red marking.
10.6.5.2.4 The red marking shall not damage the overcurrent protective devices or obscure the manufacturer's markings.
10.6.5.2.5 The circuit disconnecting means shall be accessible only to authorized personnel.
10.6.5.3 Mechanical Protection. The branch circuit(s) and connections shall be protected against physical damage.
10.6.5.4 Circuit Breaker Lock. Where a circuit breaker is the disconnecting means, a listed breaker locking device shall be installed.
10.6.5.5 Overcurrent Protection. An overcurrent protective device of suitable current-carrying capacity that is capable of interrupting the maximum short-circuit current to which it can be subject shall be provided in each ungrounded conductor.

(NFPA 72 10.6.5.2)

Findings during the inspection were:

Fire alarm circuit breaker in the main electrical room--Panels --was found missing the required lock device--locking breaker in the "ON" position.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Meridian at Stone Creek (The)
Address 1111 S 376th ST ,
City, State, Zip Milton, WA 98354

Provider Number 2365
Approval Status Disapproved
Facility Type Residential Care

On 07/22/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

22 NFPA 80 Fire Door Inspection and Testing

As a minimum, the following items shall be verified:

1. Labels are clearly visible and legible
2. No open holes or breaks exist in surfaces of wither the door or frame
3. Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.
4. The door, frame, hinges, hardware, and non combustible threshold are secured, aligned and in working order with no visible, signs of damage
5. No parts are missing or broken
6. Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7
7. The self-closing device is operational,; that is, the active door completely closes when operated from the full open position
8. If a coordinator is installed, the inactive lead close before the active lead
9. Latching hardware operates and secures the door when it is in the closed positon
10. Auxilliary hardware items that interfere or prohibit operation are not installed on the door or frame
11. No field modification to the door assembly have been preformed that void the label.
12. Meeting edge protection, gasketing and edge seals where required, are inspected to verify their presence and intertie
13. Signage affixed to a door meets the requirements listed in 4.1.4

NFPA 80, 5.2.3.5.2 (2019)

Findings during the inspection were:

- 1) Found painted fire door frame labels throughout the facility.
- 2) The following fire doors and frames had open holes due to hardware changes:
 - Mechanical room door by W214; hole above door handle
 - Corridor doors by W108; holes in door face, and in frame by door closer
 - Door between memory care and service hall; hole above door handle
 - Sevice hall door to kitchen; hole above door handle
 - Both kitchen doors to dining room; holes above deadbolt locks

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Meridian at Stone Creek (The)	Provider Number	2365
Address	1111 S 376th ST.	Approval Status	Disapproved
City, State, Zip	Milton WA 98354	Facility Type	Residential Care

On 07/22/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 08/26/2024


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12

Owner or Authorized Representative


Signature


Print Name and Title

Deputy State Fire Marshal Lysandra Davis
2502 112 ST
Tacoma WA 98445-1104
(360) 890-1822


Signature

This document was prepared by Residential Care Services for the Locator website.