



Washington State Patrol
Fire Protection Bureau

Phone: (360) 596-3900

Business Name	Valley Residential Care Inc.	Provider Number	2379
Address	14106 E 3RD AVE ,	Approval Status	Approved
City, State, Zip	Spokane Valley, WA 99216	Facility Type	Residential Care

On 02/12/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 164870

Here's a complaint of smoke detectors

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? No
3. If there was an evacuation / how many were evacuated? Staff and 28 residents.
4. If there were injuries / how many? None
5. Did the fire department respond? Yes

On February 12, 2025 a representative from the State Fire Marshals Office contacted the Facility Manager regarding complaint 164870.

The interconnected smoke detectors (not connected to fire alarm system) in the facility activated due to no apparent reason.

Alarms went off, the staff implemented fire safety procedures and evacuated residents to the outside. Residents were later evacuated to a facility nearby due to cold weather conditions. Staff were unable to determine cause of alarm and called the fire department for assistance. Smoke alarms did not stop until fire department personnel removed all devices after checking the facility. Facility manager worked with Western States (fire alarm contractor) and then purchased new smoke detectors to replace the removed devices. New smokes installed. Fire watch was implemented until new devices were installed.

Requested fire watch documents and procedures. Received.

Facility responded according to their procedures. No violations cited.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Valley Residential Care Inc.
Address 14106 E 3RD AVE ,
City, State, Zip Spokane Valley, WA 99216

Provider Number 2379
Approval Status Approved
Facility Type Residential Care

On 02/12/2025 the Office of the State Fire Marshal conducted an inspection at your facility.


Code Requirement

Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Amy Fackler Manager
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746


Signature